Warranty

All products manufactured by ICP DAS are under warranty regarding defective materials for a period of one year, beginning from the date of delivery to the original purchaser.

Warning

ICP DAS assumes no liability for any damage resulting from the use of this product. ICP DAS reserves the right to change this manual at any time without notice. The information furnished by ICP DAS is believed to be accurate and reliable. However, no responsibility is assumed by ICP DAS for its use, not for any infringements of patents or other rights of third parties resulting from its use.

Copyright

Copyright©2007 by ICP DAS Co., Ltd. All rights are reserved.

Trademark

The names used for identification only may be registered trademarks of their respective companies.

Table of Contents

1.		
	1.1 FEATURES	
	1.2 SPECIFICATIONS	
	1.3 Software and Document information	
	1.4 Hardware Information	
	1.4.1 Schematics and Dimensions of the I-7188XC(D)	
	1.4.2 Pin Assignment	
	1.4.3 Mounting the I-7188XC(D)	
	1.4.4 Block Diagram	
	1.4.5 Wiring Diagrams for Application	
	1.4.6 DI/DO wire connection	
_	1.4.7 Mounting the I/O Expansion Bus	
2.	Quick Start	
	2.1 Software Installation	
	2.2 Connect the Download Cable to the Host PC	
	2.3 Downloading Programs to the I-7188XC(D)	
	2.4 MiniOS7 Upgrade	
3.	Writing Your First Program	30
	3.1 Libraries	
	3.2 Compiler and Linker	
	3.3 The Detailed Steps for Programming	
	3.3.1 Download Turbo C++ version 1.01	
	3.3.2 Install Turbo C++ version 1.01	
	3.3.3 Set the environment variables of the system	
	3.3.4 Build and Execute the Program	
_	3.4 Building project on 64-bit platform	
4.		
	4.1 System Mapping	
	4.2 Debugging custom Programs using COM1	
	4.3 Using the Download Port as a COM Port	
	4.4 Functions and Demo Programs List	
	4.5 COM Port Comparison	
	4.6 Using the COM Ports	
	4.6.1 To print from the COM port	
	4.6.2 To Use COM1/COM2 for an RS-485 Application	
	4.6.3 To Send a Command to an I-7000 module	
	4.7 Using the Red LED and 7-SEG Display	
	4.8 Accessing the I-7188XC(D) Memory	
	4.8.1 Using Flash Memory	
	4.8.2 Using EEPROM.	
	4.9 Using the Watchdog Timer	
	4.10Using the Timer Function	
	4.11 Using Digital Input and Digital output.	
	4.12Using the I/O Expansion Bus	
	4.12.1 Definition of an I/O Expansion Bus	
	4.12.2 Reconfiguring the I-7188XC(D)	
F	4.12.3 I/O Expansion Boards	
5.	Applications	01

5.1 Embedded Controllers	76
5.2 Local Real Time Controller (RTC)	77
5.3 Remote Local Controller	78
5.4 PLC I/O Expansion Application	79
5.5 Radio Modem Application	
5.6 An Application Using 4 COM Ports	
Appendix A: What is MiniOS7	
Appendix B: MiniOS7 Utility and 7188XW	
MiniOS7 Utility	
7188XW	
Appendix C: Comparison Table	98
Appendix D: Library Function List	99
Appendix E: Compiling and linking	136
Using the TC Compiler	
Using the BC++ Compiler	
Using MSC Compiler	
Using MSVC++ Compiler	
Compiling on 64-bit platform like Windows 7 or Winodows 8 / 8.1	152
Appendix F: Glossary	163
Appendix G: Revision History	

1.Introduction

The I-7188XC(D) is a series of expandable embedded controllers designed for industry applications and can be used to replace PC or PLC devices in harsh environments. The I-7188XC(D) also has support for an I/O expansion bus, which can be used to implement various I/O functions, such as D/I, D/O, A/D, D/A, UART, Flash memory, battery backup SRAM, AsicKey and other I/O functions. Most types of I/O function can be implemented using this bus. ICP DAS offers more than 20 types of I/O Expansion Board for the I-7188XC(D), which can be used to expand the features of the controller. Depending on the type of embedded firmware programs that are being developed, and which I/O Expansion Board, the I-7188XC(D) can be used as a single versatile controller.

Package List

In addition to this manual, the shipping package includes the following items:

- One I-7188XC(D) module
- One download cable (CA0910)
- One companion CD containing software drivers and digital versions of the user manuals
- One copy of the release notes



Note: If any of these items are missing or damaged, please contact your local distributors for more information. We recommend that you save the shipping materials and cartons in case you want to ship the product in the future.

1.1 FEATURES


- Embedded 80188 CPU, 20M or compatible
- Cost-effective version of I-7188 series
- User defined DI/DO
- Built-in EEPROM
- 2 Built-in COM ports: COM1 and COM2
- COM driver supports both interrupt and 1K QUEUE input/output buffer
- Support for I/O expansion bus interface (Only one expansion board can be added)
- Three Digital Input Channels
- Three Open-collector output Channels
- Built-in self-tuner ASIC controller on the RS-485 port
- Optional 5 digits 7 segment display
- Built-in MiniOS7 by ICP DAS
- Program download port: COM1

1.2 SPECIFICATIONS

Flash 256K bytes (can be expanded by 512K bytes for OEM) EEPROM 2K bytes NVRAM No RTC (Real Time Clock) No Hardware Serial Number No Build-in Watchdog Timer Yes Communication Interface COM 1 RS-232/RS-485 COM 2 COM 1 RS-232/RS-485 COM 2 RS-485 COM 3 No COM 4 No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Channels 3 Output Channels 3 Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 I LED as Power/Communication Indicator 5	CPU module	
Flash 256K bytes (can be expanded by 512K bytes for OEM) EEPROM 2K bytes NVRAM No RTC (Real Time Clock) No Hardware Serial Number No Build-in Watchdog Timer Yes Communication Interface COM 1 RS-232/RS-485 COM 2 COM 1 RS-232/RS-485 COM 2 RS-485 COM 3 No COM 4 No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Channels 3 Output Channels 3 Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 I LED as Power/Communication Indicator 5	CPU	80188 CPU, 20MHz or compatible
EEPROM 2K bytes NVRAM No RTC (Real Time Clock) No Hardware Serial Number No Build-in Watchdog Timer Yes Communication Interface Communication Interface COM 1 RS-232/RS-485 COM 2 RS-485 COM 3 No COM 4 No Ethernet Port No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 19 Sigits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm -25°C to +75°C Storage Temperature -25°C to +80°C Humidity 10 to 30V/DC (non-regulated)	SRAM	128K bytes
NVRAM No RTC (Real Time Clock) No Hardware Serial Number No Build-in Watchdog Timer Yes Communication Interface COM 1 COM 1 RS-232/RS-485 COM 2 RS-485 COM 3 No COM 4 No Ethernet Port No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Open Digital Output Output Type Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity Ho to 30V/DC (non-regulated) Power requirements 10 to 30V/DC (non-regulated) P	Flash	256K bytes (can be expanded by 512K bytes for OEM)
RTC (Real Time Clock) No Hardware Serial Number No Build-in Watchdog Timer Yes Communication Interface Communication Interface COM 1 RS-232/RS-485 COM 2 RS-485 COM 3 No COM 4 No Digital Input No Input Channels 2 Contact Dry On Voltage Level Open Digital Output Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating temperature -25°C to +75°C Storage Temperature -30°C Cto +80°C Humidity Humidity 10 to 90% RH(non-condensing) Power Power requirements Power requirements 10 to 30V/DC (non-regulated) Power consumption 2.0W for I-7188XC	EEPROM	2K bytes
Hardware Serial Number No Build-in Watchdog Timer Yes Communication Interface COM 1 COM 1 RS-232/RS-485 COM 2 RS-485 COM 3 No COM 4 No Ethernet Port No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating temperature -25°C to +75°C <td>NVRAM</td> <td>No</td>	NVRAM	No
Build-in Watchdog Timer Yes Communication Interface RS-232/RS-485 COM 1 RS-232/RS-485 COM 2 RS-485 COM 3 No COM 4 No Ethernet Port No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display I 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -25°C to +80°C Humidity 10 to 90% RH(non-condensing) Power requirements 10 to 30V/DC (non-regulated) Power requir	RTC (Real Time Clock)	No
Communication Interface COM 1 RS-232/RS-485 COM 2 RS-485 COM 3 No COM 4 No Ethernet Port No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating Environment Operating Environment Operating Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements Power consumption 2.0W for I-7188XC	Hardware Serial Number	No
COM 1 RS-232/RS-485 COM 2 RS-485 COM 3 No COM 4 No Ethernet Port No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Channels 3 Output Channels 3 Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements Power requirements <	Build-in Watchdog Timer	Yes
COM 2 RS-485 COM 3 No COM 4 No Ethernet Port No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display I 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC	Communication Inter	face
COM 3 No COM 4 No Ethernet Port No Digital Input Input Channels Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC 2.0W for I-7188XC	COM 1	RS-232/RS-485
COM 4 No Ethernet Port No Digital Input Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels 3 Output Channels 3 Output Channels 3 Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power 10 to 30V/DC (non-regulated) 2.0W for I-7188XC	COM 2	RS-485
Ethernet Port No Digital Input Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Open Digital Output Output Channels 3 Output Channels 3 Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC	COM 3	No
Digital Input Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power 2.0W for I-7188XC	COM 4	No
Input Channels 2 Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC 2.0W for I-7188XC	Ethernet Port	No
Contact Dry On Voltage Level Connect to GND Off Voltage Level Open Digital Output Output Channels Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating Environment -25°C to +75°C Storage Temperature -25°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC 2.0W for I-7188XC	Digital Input	
On Voltage Level Connect to GND Off Voltage Level Open Digital Output Open Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC	Input Channels	2
Off Voltage Level Open Digital Output Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC 2.0W for I-7188XC	Contact	Dry
Digital Output Output Channels 3 Output Type Open-collector Max Load Current 100mA Load Voltage +30V/DC Max. LED Display 1 1 LED as Power/Communication Indicator 5 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements Power consumption 2.0W for I-7188XC	On Voltage Level	Connect to GND
Output Channels3Output TypeOpen-collectorMax Load Current100mALoad Voltage+30V/DC Max.LED Display1 LED as Power/Communication Indicator5 digits 7 segment display (for I-7188XCD only)Dimensions119mm x 72mm x 33mmOperating EnvironmentOperating temperature-25°C to +75°CStorage Temperature-30°C to +80°CHumidity10 to 90% RH(non-condensing)PowerPower requirements10 to 30V/DC (non-regulated)2.0W for I-7188XC	Off Voltage Level	Open
Output TypeOpen-collectorMax Load Current100mALoad Voltage+30V/DC Max.LED Display11 LED as Power/Communication Indicator5 digits 7 segment display (for I-7188XCD only)Dimensions119mm x 72mm x 33mmOperating EnvironmentOperating temperature-25°C to +75°CStorage Temperature-30°C to +80°CHumidity10 to 30V/DC (non-regulated)Power requirements10 to 30V/DC (non-regulated)Power consumption	Digital Output	
Max Load Current100mALoad Voltage+30V/DC Max.LED Display1 LED as Power/Communication Indicator5 digits 7 segment display (for I-7188XCD only)Dimensions119mm x 72mm x 33mmOperating EnvironmentOperating temperature-25°C to +75°CStorage Temperature-30°C to +80°CHumidity10 to 90% RH(non-condensing)PowerPower requirements10 to 30V/DC (non-regulated)2.0W for I-7188XC	Output Channels	3
Load Voltage+30V/DC Max.LED Display1 LED as Power/Communication Indicator5 digits 7 segment display (for I-7188XCD only)Dimensions119mm x 72mm x 33mmOperating EnvironmentOperating temperature-25°C to +75°CStorage Temperature-30°C to +80°CHumidity10 to 90% RH(non-condensing)PowerPower requirements10 to 30V/DC (non-regulated)2.0W for I-7188XC	Output Type	Open-collector
LED Display1 LED as Power/Communication Indicator5 digits 7 segment display (for I-7188XCD only)Dimensions119mm x 72mm x 33mmOperating EnvironmentOperating temperature-25°C to +75°CStorage Temperature-30°C to +80°CHumidity10 to 90% RH(non-condensing)PowerPower requirements10 to 30V/DC (non-regulated)2.0W for I-7188XC	Max Load Current	100mA
1 LED as Power/Communication Indicator 5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC 2.0W for I-7188XC	Load Voltage	+30V/DC Max.
5 digits 7 segment display (for I-7188XCD only) Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC	LED Display	
Dimensions 119mm x 72mm x 33mm Operating Environment Operating temperature -25°C to +75°C Storage Temperature -30°C to +80°C Humidity 10 to 90% RH(non-condensing) Power Power requirements 10 to 30V/DC (non-regulated) 2.0W for I-7188XC	1 LED as Power/Commun	ication Indicator
119mm x 72mm x 33mmOperating EnvironmentOperating temperature-25°C to +75°CStorage Temperature-30°C to +80°CHumidity10 to 90% RH(non-condensing)PowerPower10 to 30V/DC (non-regulated)Power consumption2.0W for I-7188XC	5 digits 7 segment display	(for I-7188XCD only)
Operating EnvironmentOperating temperature-25°C to +75°CStorage Temperature-30°C to +80°CHumidity10 to 90% RH(non-condensing)PowerPower requirements10 to 30V/DC (non-regulated)Power consumption2.0W for I-7188XC	Dimensions	
Operating temperature-25°C to +75°CStorage Temperature-30°C to +80°CHumidity10 to 90% RH(non-condensing)PowerPowerPower requirements10 to 30V/DC (non-regulated)Power consumption2.0W for I-7188XC	119mm x 72mm x 33mm	
Storage Temperature-30°C to +80°CHumidity10 to 90% RH(non-condensing)PowerPower requirementsPower requirements10 to 30V/DC (non-regulated)Power consumption2.0W for I-7188XC	Operating Environme	nt
Storage Temperature-30°C to +80°CHumidity10 to 90% RH(non-condensing)PowerPower requirementsPower requirements10 to 30V/DC (non-regulated)Power consumption2.0W for I-7188XC	Operating temperature	-25°C to +75°C
Power Power requirements 10 to 30V/DC (non-regulated) Power consumption 2.0W for I-7188XC	Storage Temperature	-30°C to +80°C
Power requirements10 to 30V/DC (non-regulated)Power consumption2.0W for I-7188XC	Humidity	10 to 90% RH(non-condensing)
Power consumption 2.0W for I-7188XC	Power	
Power consumption 2.0W for I-7188XC	Power requirements	10 to 30V/DC (non-regulated)
	•	
3.0W for I-7188XCD		3.0W for I-7188XCD

1.3 Software and Document information

The location of all documents and software related to the I-7188XC(D) on the companion CD are shown in the following directory tree. The relevant file can quickly be located by referring to the tree.




The documents and software listed above can also be obtained from the ICP DAS website: http://ftp.icpdas.com/pub/cd/8000cd/napdos. The folder location of all documents and software on the website is identical to the companion CD.

The **iobus_e.pdf** file that is provided in the


CD:\Napdos\7188XABC\Xboard\Document\ folder and the "I/O Expansion Bus for 7188X/7188E User's Manual" contain the same content, so the user can refer to either document for more details related to the I-7188XC(D) I/O expansion bus. Before continuing, it is recommended that you read the **Readme.html**, which can be found in the **CD:\Napdos\7188XABC\7188XC**. The latest information available prior to shipping will be contained in this file.

1.4 Hardware Information

1.4.1 Schematics and Dimensions of the I-7188XC(D)



1.4.2 Pin Assignment




The pin assignment of 14-pin screw terminal block is as follows:

Pin	Name	Description
1	X3	Connects to I/O expansion board
2	X2	Connects to I/O expansion board
3	X1	Connects to I/O expansion board
4	DO3	Digital output, 100mA, 30V Max.
5	DO2	Digital output, 100mA, 30V Max.
6	DO1	Digital output, 100mA, 30V Max.
7	DI3	Digital input, 3.5V ~ 30V
8	DI2	Digital input, 3.5V ~ 30V
9	INIT*	Initial pin

10	D2+	DATA+ pin for COM2 (RS-485)
11	D2-	DATA- pin for COM2 (RS-485)
12	+VS	V+ of power supply (+10 to +30V/DC, unregulated)
13	GND	GND for the power supply

The pin assignment for the COM1 connector (DB-9 Male) is as below:




DB9-Male (COM1)

Pin	Name	Description
1	D1+	DATA+ for RS-485
2	TXD	Transmit Data
3	RXD	Receive Data
4	N/C	No Connection
5	GND	Signal ground for RS-232
6	N/C	No Connection
7	CTS	Clear To Send (RS-232)
8	RTS	Request To Send (RS-232)
9	D1-	DATA- for RS-485


Note: The COM1 can be used as either an RS-232 or RS-485 port. It is not recommended to use both RS-232 and RS-485 at the same time.

1.4.3 Mounting the I-7188XC(D)


1. Din-Rail Mounting




2. Stack Mounting




1.4.4 Block Diagram





Note: Connect the DB-9 of the download cable to the COM Port of PC.


Using a 3-wire RS-232 Port



Note: There are 3 wires as follows:

- Connect the RXD to the TXD of the RS-232 device
- Connect the TXD to the RXD of the RS-232 device
- Connect the GND to the GND of the RS-232 device


Using a 5-wire RS-232 Port



Note: There are 5 wires as follows:

- Connect the RXD to the TXD of the RS-232 device
- Connect the TXD to the RXD of the RS-232 device
- Connect the RTS to the CTS of the RS-232 device
- Connect the CTS to the RTS of the RS-232 device
- Connect the GND to the GND of the RS-232 device

Using the RS-485 Port



Note: The RS-485 interface can directly drive up to 256 I-7000 series modules without the need for a repeater.

1.4.6 DI/DO wire connection


Digital Input Wire Connection

Input Type	ON State DI value as 0	OFF State DI value as 1
Relay Contact	Relay Close	Relay Open
TTL/CMOS Logic	Logic Level Low Logic GND V	Logic Level High Logic GND V
Open Collector		


Digital Output Wire Connection

Input Type	ON State DO value as 1	OFF State DO value as 0
Drive Relay		$\begin{array}{c c} \hline & & & & \\ \hline & & & & \\ \hline & & & & \\ \hline & & & &$
Resistance Load		$\stackrel{+}{\longrightarrow} \times \stackrel{+}{=} \bigcirc \bigcirc$

1.4.7 Mounting the I/O Expansion Bus Before mounting:



After mounting:




2. Quick Start

2.1 Software Installation

Step 1: Insert the companion CD into the CD drive.

- Step 2: Copy the 7188XC folder from **CD:\Napdos\7188XABC** to the Hard Drive of the Host PC.
- Step 3: Install the MiniOS7 Utility. Locate and execute the **minios7_utility_v311.exe** file from CD:\NAPDOS\MINIOS7\UTILITY\MiniOS7_utility\ folder or http://ftp.icpdas.com/pub/cd/8000cd/napdos/minios7/utility/minios7_ utility/
- Step 4: Copy the **7188xw.exe** file from the CD:\Napdos\MiniOS7\utility\ folder to the PATH directory, for example **C:\Windows**.


After all the software is copied to the Host PC, the content of 7188XC folder should be as follows:




"C:\Windows\" folder to allow it to be executed from any location.

2.2 Connect the Download Cable to the Host PC

- Step 1: Connect the CA0910F download cable between COM1 of the I-7188XC(D) and the COM Port of the Host PC, as shown in the diagram below.
- Step 2: Apply power (Vs+, GND) to the I-7188XC(D). Vs+ can be in a range from +10V to +30V DC.




Step 3: After applying the power, the 5-digits of the 7-SEG LED will continuously show as follows.



If the non-display version of module is being used, please continue to the next step.

Step 4: Check that the red LED continuously blinks one times and wait for one second to next cycle. The diagram show as follows:



Note: Only the display version of the module will include a 5-digit 7-SEG LED.

2.3 Downloading Programs to the I-7188XC(D)

Before using the MiniOS7 Utility, ensure that the download cable is connected from the Host PC to the I-7188XC(D) and ensure that no other programs are running on the I-7188XC(D). For details of how to connect between the I-7188XC(D) and COM1 on the Host PC, refer to the wiring diagram in the Sec.1.4.5---Program download.


Note: Instead of using the MiniOS7 Utility to download programs to the I-7188XC(D), the 7188xw.exe file can also be used. Refer to **Appendix B: MiniOS7 Utility and 7188XW** for details of the program download procedure for 7188xw.exe.

The program download procedure is as follows (Refer to Sec2.1 to install MiniOS7 Utility Ver 3.11):

Step 1: From the Windows START menu, go to Programs/ICPDAS/MiniOS7 Utility Ver 3.11/and locate the MiniOS7 Utility Ver3.11.

💼 ICPDAS	•	💼 MiniOS7 Utility Ver 3.11	• i	🆄 MiniOS7 Utility Ver 3.11
				😵 MiniOS7 Utility Ver 3.11 Manual
			1	🛃 Uninstall

Step 2: Press Connection and Select "New connection". Choose the right COM port and set other parameters. Click **OK** button and the utility will search module automatically.




	🖄 Connection 📃 🗖 🗙
	Connection History
(2)	COM1
	Serial Port
	Baud Rate: 115200 V IP: 192.168.255.1
	Data Bit: 8 🛛 Port: 10000
	Parity: 0(None)
	Stop Bit: 1
	OK Cancel <u>H</u> elp

Step 3: See if the MiniOS7 Utility connects with I-7188XC. The connected icon is . The disconnected icon is




MiniOS7 Utility Verion 3.1.1 (build 3.1		'ools 🥔 Help 🔻	- 🗆 🗙
Look jn: 🛅 MiniOS7_Utility	v	Lock in: Disk A	(3)
Name Size in in FIRMWARE Size OS_IMAGE Size icpdas 1KE load232.dll 88KE MiniOS7_Utility.chm 1,025KE MiniOS7_Utility.chm 1,025KE MiniOS7_Utility.chm 3KE MiniOS7_Utility.ini 3KE uart.dll 56KE unins000.dat 9KE igHunins000.exe 662KE	File Folder File Folder File Folder 細際網路捷徑 應用程式擴充 已編譯的 HTML H 應用程式 組態設定值 應用程式擴充 DAT File 應用程式	See here to know connect status.	M dified
Connection(F2)	Tool(F6)		»

Step 4: Select the file to load from left side and click ^{[] Upload[5]} to load file into module or draw the file to the right side.



Step 5: Select the file and then press the right mouse button. Choose the **Run** and press to execute the program.




Step 6: The result of the program will be shown in 7188xw window.

Look in: 🛅 hello	~ (3 🗇 🖻		Lock in: Disk A	~	188,910 byte	es available	- [
Name	Size Type	e	No	Name		Size		Modifie
🗍 7188xa 🖬 7188xaL 🛛 🐂 🚃	31KB H File		5 🖾 0	hello.exe		7,634	4/30/200	7 11:34:2
Aut	8x for WIN32 versi gin Key Thread] oRun:	On 1.31 (200 Current set:	Use CC	M1 115200,N,	lim Isai 8,1	-1	-	
188×CL Aut hello Cur HELLO HELLO	ondownload files: N rent work director ginal baudrate = 1 baudrate = 115200	y="C:\Docume	ents and	.Settings∖vi	c\Desktop	\hello"		
I 7188×CL Aut hello Cur HELLO 이 이 이 이 이 이 이 이 이 이 이 이 이 이 이 이 이 이	odownload files: N rent work director ginal baudrate = 1	y="C:\Docume	ents and	Settings\vi	c\Desktop	\he 11o ''		
Image: Provide and Provid	odownload files: N rent work director ginal baudrate = 1 baudrate = 115200 88XC>run #0	y="C:\Docume	ents and	Settings\vi	c∖Desktop	\he 11o ''		

NOTE: The 7188xw window has to be closed and then the download operation (Step 4) could be done.

The content of the Hello.c file is as follows:



2.4 MiniOS7 Upgrade

ICP DAS will continue to add additional features to the MiniOS7 in the future, so it is recommended that you periodically check the ICP DAS website for the availability of updated versions of the MiniOS7.

Note: For a more detailed description of the MiniOS7, please refer to **Appendix A: What's the MiniOS7**.

The MiniOS7 Utility provides an easy way to upgrade MiniOS7. The upgrade procedure is as follows:

Step 1: Get the latest version of MiniOS7 image file.

The format of the image file name is: **TTYYMMDD.img**

TT: TYPE of product.


YY: The year this image released

MM: The month this image released

DD: The day this image released

Note: The MiniOS7 image file contained on the companion CD can be found in CD:\NAPDOS\MiniOS7\ directory. The latest version of MiniOS7 can be downloaded from the ICP DAS website: http://ftp.icpdas.com/pub/cd/8000cd/napdos/7188xabc/7188xc/os image/


Step 2: Execute the MiniOS7 Utility. Refer to Step2 in Sec2.3 to connect the module. Select the MiniOS7 image file that you want to upgrade on the left side. Click the right mouse button to choose the "**Update MiniOS7 Image**".



Step 3: It will take about 10 seconds for the upgrade to finish. If the MiniOS7 was updated successfully, a **Confirm** action dialog box will appear.

Loading Progress	
From: E:\070412vic\minos7\xc_img\7188XC-20070301.IMG To: [SRAM]7188XC-20070301.IMG	
51 <mark>%</mark>	
Cancel	Help
MiniOS7 Utility Verion 3 X Please wait a while for rebooting	
OK	

Step 4: Press button and see the "Build" item to check the version number of the MiniOS7. The diagram is as follow:



catego	y key	value
ocalHost Basic	Prompt	i7188×C
asic Basic	OS .	MiniOS7
1emory Basic	Hardware	I-7188×C
letwork Basic	Build	Version 2.00 006 Mar 01 2007 16:20:53
omPort Basic	Time	N/A
Basic	Init* pin	Open
Basic	CPU	RDC 8820-D
Basic	Reset by	Power ON reset
ComPo	rt COM1	73057,0,0,0
ComPo	rt COM3	17301510,58,4,0
ComPo	rt COM4	1094996035,83,45,55
ComPo	rt COM5	0,0,0,0
ComPo	rt COM6	0,0,0,0
ComPo	rt COM7	134219264,1,58,4
ComPo	rt COM8	1146110793,65,83,45
LocalH	ost OS Version	Windows XP SP2
LocalH	ost Physical Memory	536M
LocalH	ost CPU Frequency	2820
LocalH	ost IP Address	10.0.8.9
LocalH	ost ComPort	COM1,COM2,COM7,COM8,COM10
Memory	SRAM	128K
<		

Note: Besides using the MiniOS7 Utility to upgrade the MiniOS7, 7188xw.exe can also be used. Refer to **Appendix B: MiniOS7 Utility and 7188XW** for download procedures.

3.Writing Your First Program

3.1 Libraries

ICP DAS provides the 7188xcl.lib function library for the I-7188XC(D) module. The 7188xcl.lib is for programs of the large memory model and is suitable for TC, BC++, MSC and MSVC++ compilers. All declared functions are described in the header file, **7188xc.h**.

The location of latest Library:

http://ftp.icpdas.com/pub/cd/8000cd/napdos/minios7/minios7_2.0/i-718 8xc/lib/ or CD: \Napdos\MiniOS7\MiniOS7_2.0\i-7188xc\lib

Function description	Example
COM port	InstallCOM1, InstallCOM2, InstallCOM3
	IsCOM1, IsCOM2, IsCOM3
	ToCOM1, ToCOM2, ToCOM3
	ReadCom1, ReadCom2, ReadCom3
EEPROM	WriteEEP, ReadEEP, EnableEEP, ProtectEEP
LED and 5-digit LED	LedOn, LedOff, Init5DigitLed, Show5DigitLedWithDot
Flash Memory	FlashReadId, FlashErase, FlashRead,
	FlashWrite
Timer and Watchdog Timer	TimerOpen, TimeClose, TimerResetVlaue,
	TimerReadValue, StopWatchReset,
	StopWatchRead, StopWatchStop
File	GetFileNo, GetFileName, GetFilePositionByNo,
	GetFilePositionByName
Connect to 7000 series	SendCmdTo7000, ReceiveResponseFrom7000
modules	
Programmable I/O	SetDio4Dir, SetDio4High, SetDio4Low, GetDio4
Others	Kbhit, Getch, Putch, LineInput, Scanf

Hundreds of functions are supported in the 7188xcl.lib files as follows:

Note: For a more detailed description of the functions, please refer to **Appendix D: Library Function List.**

3.2 Compiler and Linker

A C Language compiler must be used to develop any applications. Valid compilers include:

- BC++ 3.1~5.02
- TC++ 1.01
- TC 2.01
- MSC
- MSVC++ (Prior to version 1.52).


ICP DAS suggests that BC 3.1 is used as the compiler as the libraries provided have been created using the BC 3.1 compiler. Special attention should be paid to the following items before using the compiler to develop custom applications:

- Generate a standard DOS executable program.
- Set the CPU to 80188/80186
- Set the floating point to EMULATION if floating point computation is required. (Make sure not to choose 8087)
- Cancel the Debug Information function as this helps to reduce program size. (MiniOS7 supports this feature.)


3.3 The Detailed Steps for Programming 3.3.1 Download Turbo C++ version 1.01

Free versions of the Turbo C 2.01 and Turbo C++ 1.01 compilers can be downloaded from the Borland website. The following instructions will help you to install the Turbo C++ version 1.01 compiler on a PC running a Windows operating system.


Step 1: Go to the CodeGear web site (http://dn.codegear.com/museum).



Step 2: Scroll down the bar and click on the link for Antique Software: Turbo C++ version 1.01 to go to the download page.




Step 3: Click on the link for **Turbo C++ version 1.01**, as shown below, to download the **tcpp101.zip** file. When requested, save the file to a safe location.



3.3.2 Install Turbo C++ version 1.01

- Step 1: Go to where you downloaded the file, and double click on the self-extracting file (tcpp101.zip) in Windows to extract it. This will open a WinZip Self-Extractor window (you do NOT need WinZip installed on your machine). By default, this will extract the files to the C:\tctemp directory. You may designate a different location.
- Step 2: Once the files have been extracted, exit the WinZip Self-Extractor window.




Step 3: Open an MS-DOS command prompt window.


Step 4: Change the directory to the **c:\tctemp** (or wherever you put the unzipped files folder), and execute the **INSTALL.EXE** file.

C:\WINDOWS\System32\cmd.exe	- 🗆 🗙
Microsoft Windows XP [Version 5.1.2600] (C) Copyright 1985-2001 Microsoft Corp.	
C:\Documents and Settings\Administrator cd c:\tctemp	1.1
C:\tctempinstall.exe_4.2	


Step 5: The following instructions will guide you through the installation process.



- Step 5.1: Press < ENTER > to start the installation
- Step 5.2: Select the **drive** where the unzipped file is located. The default is "A", so you should enter **"C"**, then press **<ENTER>**.
- Step 5.3: Press <**ENTER**> again. This will install the software from the directory \tctemp.
- Step 5.4: Press <**ENTER**> again. This allows Turbo C to be installed on the Hard Drive.
- Step 5.5: Use the Up/Down arrow keys (Press the up arrow once) to select Start Installation, and then press **<ENTER>** again.




Step 5.6: At this point, the Turbo C++ version 1.01 compiler is installed in C:\TC, which is where the tcc.exe executable is also located.



3.3.3 Set the environment variables of the system

After installing, you must add C:\TC to your executable search path. The easiest way to do this is as follows:

Step 1: Right-click on the **My Computer** icon on the desktop. (Under Windows XP, the My Computer icon may be located in the start <u>menu</u>) and choose **Properties** from the context menu.



Step 2: Click on the **Advanced** tab, and then click on the **Environment Variables** button.

System Properties	Environment Variables	? 🗙
System Restore Automatic Updates Renot General Computer Name Hardware Advard	User variables for Administrator	
You must be logged on as an Administrator to make most of these chang Performance Visual effects, processor scheduling, memory usage, and virtual merrory Settings	Variable Value TEMP C:\Documents and Settings\Administrat TMP C:\Documents and Settings\Administrat	
User Profiles Desktop settings related to your logon Settings	New Edit Delete System variables Variable Value	
Startup and Recovery System startup, system failure, and information Settings Environment Variables Error Reporting	Variable Value Spec C:\WINDOWS\system32\cmd.exe HOST_C NO _OF_3 4 Windows_NT C:\WINDOWS\system32;C:\WINDOWS; New Edit Delete	
OK Cancel A		el

- Step 3: In **System variables,** choose the variable **Path** and then click on the **Edit** button.
- Step 4: Add the target directory to the end of the Variable value using a semi-colon as a separator. For example "C:\TC\BIN;C:\TC\INCLUDE;".

Environment Varia	ables ? 🗙
Edit System Va	riable ?X
Variable name: Variable value:	Path es\GTK\2.0\bh;C:\TC\BIN;C:\TC\INCLUDE; OK Cancel
System variables	Value
ComSpec FP_NO_HOST_C. NUMBER_OF_3 OS Path	
	New Edit Delete


Step 5: Click the **OK** button, and then restart your computer in order for your changes to take effect.

3.3.4 Build and Execute the Program

Step 1: Open the MS-DOS command prompt window in the same way as you did in step 3 of the Install Turbo C++ version 1.01 instructions.

NOTE: You must close the original MS-DOS command prompt window first.

Step 2: Type "d:" and then press **<Enter>** to enter D drive letter. Step 3: Type "cd 7188XC_test" and press **<Enter>**.



- **NOTE:** Assume there is a folder,7188XC_test, built under d:\. There is a 7188xc.h and 7188xcl.lib in the 7188XC_test folder.
- Step 4: Type **tc** and press **<ENTER>** to run the TC++ 1.01 Integrated Environment. This command can be executed from any location.

File Edit Search Run Compile Debug Project Options Window Help NONAMEØØ.C 11[1]
=[T]===================================
1-1-1-About
Turbo C++
Version 1.01
Copyright (c) 1990 by
Borland International, Inc.
1 Help Accept the settings in this dialog box

Step 5: Create a source file (*.c). Step 5.1: Select **New** from the File menu.

File Ed	it <mark>S</mark> earc	h Run	Compile	Debug	Project	Options	Window	Hel
New	гэ	D						
Save as Save al		T						
Change Print Get inf DOS she	0							
Quit	11 Alt-X							
]						

Step 5.2: Type in following code. Note that the code is case-sensitive.

∂		
#1	include "7188xc.h"	
vo	oid main(void)	
{	InitLib();	
	Print("Hello world!\r\n");	
ر ب ب		


Step 5.3: Save the file by selecting **Save** from the File menu, and then enter the file name **Hello.C**.

ex (Command Prompt - tc
≡ #i vo {	File Edit Search Run Compile Debug Project Options Window Help NONAME00.C Save F2 Save all Change dir Print Get info DOS shell Quit Alt-X
F1	Help Save the file in the active window

Save File As $5.3.2$ As =	
D:\7188XC~1\hello.C	OK
iles	
	Cancel .
	Help
D:\7188XC~1\NONAME00.CPP Directory	12:00am

Note: If you have a text editor you are familiar with, you may use it to type in the above code. It should be noted that you cannot use a word processor application for this, as you must use an application that saves in plain text, such as notepad or edit. C language program files should always be given a name ending in "**.C**".

Step 6: Create a new project file (*.prj).




Step 6.1: Type the name of the project file and then click the **OK** button.

	——— Open Project File	e
Hello.P	iect File	OK -
liles		
>		
		Gance 1
51		Help
D:\7188XC	~1*.PRJ	10.00
	Directory	12:00am


Step 7: Add all necessary files to the project.

C:\WINDOWS\System32	%cmd.exe - e:\tc\bin\tc		- 🗆 🗙
≡ File Edit Sea	rch Run Compile Debu NONAME00.	g Project Options	Window Help
(Add item	Open project Close project Add item Local options Include files	2
<u>1:1</u>			
r=[]]			3=[†]
File name Loc	ation	Lines (Code Data A
F1 Help Add an it	em to the project		
· · ·	-		

Step 7.1: Select the source file. Type "*.c" and press **Enter** in A area. If the file you want is in B area, moving the green block to choose the file and click the **Add** button. If not, moving the green block to C area and press **Enter** to search the file.




Step 7.2: Select the function library. Type "*.lib" and press **Enter** in A area. If the file you want is in B area, moving the green block to choose the file and click the **Add** button. If not, moving the green block to C area and press **Enter** to search the file.




Step 8: Click **Done** to exit.

= File Edit Search Run Com		ject Options	Window	Hel
#include "	- HELLO.C	I Full mer	านร	Off
void main(void) { InitLib(); Compiler Make Directories				
Print("Hello world!\r\n"); Environment			•	
		Save		1
Full menu	5			
7:26				=2=[
7:26	5 Project: HELLO =	Lines	Code n∕a	=2=[Data n∕a


Step 10: Click on "**Options**" and select the compile menu item, then set the **Code generation options**.



Step 10.1: Change the Memory model (Small for 7188xcs.lib, large for 7188xcl.lib).



Step 10.2: Click on "**More...**", then set the Floating Point to **Emulation** and the **Instruction Set** to **80186**.




Step 11: Click on "**Options**" and select "**Directories…**" to enter the TC++ 1.01 include and library directories. By default, the directories are same as the installation directory of the TC++



Note: The Include Directories specifies the directory that contains the standard include files. The Library Directories specifies the directories that contain the TC++ 1.01 startup object files and run-time library files.

Step 12: Click on "**Compile**" and select "**Make EXE file**" to make the project.



For instructions related to the downloading and execution of programs, please refer to Section 2.3.

Ø

ă

Warnings: Ø

Available memory: 394K

Errors: Ø

For more detailed information regarding compiling and linking related to the various C compilers (TC/BC/MSC/MSVC), please refer to **Appendix E: Compiling and linking.**

3.4 Building project on 64-bit platform

If trying to use 16-bit compiler like BC3.1 or TC++3.0 to build MiniOS7 project on Windows 64-bit platform like Windows 7 or Windows 8, it will prompt up an error message to show compatibility problem for 64-bit platform.

Please refer to the section "Compiling on 64-bit platform like Windows 7 or Windows 8 / 8.1" in Appendix E Compiling and linking.

4. Operating Principles

4.1 System Mapping

Device	Address mapping
Flash ROM	256K: from C000:0000 to F000:FFFF
SRAM	128K: from 0000:0000 to 1000:FFFF
COM1 BASE	0XFF80 to 0XFF88
COM2 BASE	0XFF10 to 0XFF18

Interrupt No.	Interrupt mapping
0	Divided by zero
1	Trace
2	NMI
3	Break point
4	Detected overflow exception
5	Array bounds exception
6	Unused opcode exception
7	ESC opcode exception
8	Timer 0
9	Reserved
0A	DMA-0
0B	DMA-1
0C	\INT0 of the I/O expansion bus
0D	\INT1 of the I/O expansion bus
10	Reserved
11	COM2
12	Timer 1
13	Timer 2
14	COM1

4.2 Debugging custom Programs using COM1

The COM1 Port (download port) of the I-7188XC(D) has three major functions.

- Downloading programs from the Host PC
- Connecting to the Host PC to enable program debugging
- Acting as a general-purpose COM port

When the I-7188XC(D) is switched on, it will initialize COM1 in the following configuration under **console mode**:

- Start Bit=1, Data Bit=8, Stop Bit=1, no parity
- Baud Rate=115200 bps

The I-7188XC(D) will check the status of the INIT* pin. If the INIT* pin is shorted to the GND pin, the I-7188XC(D) will send the start up information to COM4 and enter console mode to allow the user to download/debug a program, and the following start up messages will be displayed.

- Power off the Host PC and I-7188XC(D)
- Connect the download cable between COM4 on the I-7188XC(D) and the COM Port of the Host PC (refer to Section 2.2 for more details)
- Switch on the power for the Host PC and execute the 7188xw.exe
- Switch on the power for the I-7188XC(D)
- All initialization messages will be shown on the monitor of the Host PC

If the INIT* pin is open, the I-7188XC(D) will search for the autoexec.bat file. If the autoexec.bat file is present, the I-7188XC(D) will execute it. If the autoexec.bat file is not present, the I-7188XC(D) will revert to console mode to allow the user to download/debug a program.

After completing the initialization stage, the I-7188XC(D) will use the COM1 as its standard input/output. The standard output of the I-7188XC(D) will be shown on the monitor of the Host PC. If a key is pressed on the keyboard of the Host PC, the key code will be echoed to the I-7188XC(D) as standard input. Therefore both the keyboard and

monitor of the Host PC can be used as standard input and output for the I-7188XC(D) as follows:

- Use 7188xw.exe or MiniOS7 Utility as a bridge between the I-7188XC(D) and the Host PC
- Execute 7188xw.exe or the MiniOS7 Utility on the Host PC to setup this bridge
- The keyboard of the Host PC \rightarrow standard input of I-7188XC(D)
- The monitor of the Host PC \rightarrow standard output of I-7188XC(D)

In this way, the I-7188XC(D) can read data from the keyboard and display it on the monitor. Thus, debugging a program will be easies and effective.

Note: 7188xw.exe and the MiniOS7 Utility are provided on the companion CD. Please refer to Section 2.2 for detailed wiring information and Section 2.3 for details of how to download programs.

4.3 Using the Download Port as a COM Port

The download port (COM1) of the I-7188XC(D) can be used as a general purpose RS-232 port in the following manner:

- Step 1: Download custom programs and autoexec.bat to I-7188XC(D) first.
- Step 2: Switch off the I-7188XC(D) and remove the download cable from the Host PC.
- Step 3: Disconnect the INT* pin from the GND pin of the I-7188XC(D) if they are connected.
- Step 4: Switch on the I-7188XC(D) (no standard input, no standard output, no debug information).
- Step 5: Connect a download cable between a new RS-232 device and the COM1 of the I-7188XC(D).
- Step 6: Initialize the COM1 to the new configuration.
- Step 7: The COM1 of the I-7188XC(D) can now be used a general purpose RS-232 port.

4.4 Functions and Demo Programs List

There are several demo programs that designed for I-7188XC(D). For more detailed information regarding these programs, please refer to the contents in later sections. The functions of the demo programs are as follows:

Folder	Demo program	Explanation	Section
	Hello_C	Detecting if the operation system is	3.3.4
Hello	Hello_C++	MiniOS7. Note: MSC does not support C++ language. The Hello_C++ file is only supported by BC.	
	C_Style_IO	 Shows how to write a function to input data. Shows how to retrieve a string. Shows how to use a C function: sscanf, or just use Scanf(). 	
COM Dort	Receive	Receive data from the COM Port.	4.6
COM_Port	SIv_COM	The PC sends commands to the I-7188XC(D), and receives responses from the I-7188XC(D). Also shows how to use another COM Port or LED to show information to help debug a program.	4.0
	ToCom_In_Out	Reads/writes the byte data via the COM Port.	
IO_PIN	N Reads/writes the DO and DI of the I-7188XC(D).		4.11
LED	Led	Shows how to use the DelayMs function to switch the LED ON or OFF.	4.7
	Seg7led	Controls the red LED and 5-digit 7-segment LED.	4.7
	Config_1_Basic	In many applications, a text file is needed in order to record specific information so that the program can read it. FSeek can be used to retrieve specific information from a text file.	
File	Config_2_Advanced	Extends config_1_Basic, and adds GetProFileInt, GetProFileFloat and GetProFileStr. These functions can be used to determine the "Type" from a text file.	
	EEPROM	Writes a value to the EEPROM and shows it on the monitor.	

	EEPROM-r	Reads the data that has been written to the EEPROM.	
	EEPROM-w	Inputs a value and stores it in an EEPROM block 1 peer address (value will automatically increase by 1).	
	Flash	Reads, writes and erases the Flash memory.	
	Flash-r	Reads the value that has been written to the Flash memory.	
	Flash-w	Inputs a value written in the Flash memory (value will automatically increase by 1).	
	Demo5	Shows how to access the NVRAM.	
	NVRAM-r	Reads the value that has been written to NVRAM.	
	NVRAM-w	Writes a value to the NVRAM (value will automatically increase by 1).	
	Top-Mem	Demonstration of the AllocateTopMemory function	
	Reset	Restores the initial values.	
Misc	Runprog	Uses the Ungetch function to run another program.	
	Watchdog	Enables the Watchdog or bypasses the enabled Watchdog.	4.9
7K87K_Module	7K87K_demo_for_com 7K87K_AI_for_Com 7K87K_DI_for_Com 7K87K_DIO_for_Com	Show how to connect and control the 7k or 87k series modules via COM2.	4.6.3
	7k87K_DO_for_Com	-	
	AO_024_for_Com	4	
	AO_22_26_for_Com		
	Demo90	A demonstration program showing how to use the Timer function.	
	Demo91	Show how to use the CountDownTimer function on channel 0 to switch the LED ON or OFF.	
Timer	Demo92	Shows how to use the StopWatch function on channel 0 to switch the LED ON or OFF.	4.10
	Demo96	Shows how to use the InstallUserTimer function to control the 5-digit 7-segment LED.	
	Demo97	Shows how to use the DelayMs function to switch the LED ON or OFF.	

	Demo98	Shows how to use the I-7188XC(D) timer function to send/receive data to or from 7000 series modules.	
XBoard		These are demo programs for all I/O expansion boards that are applicable to the I-7188XC(D).	4.12

4.5 COM Port Comparison

The I-7188XC(D) COM ports are as follows:

COM Port	Hardware	
COM1	80188's on-chip UART-0, 5-wire RS-232 or 2-wire RS-485	
COM2	80188's on-chip UART-1, 2-wire RS-485	

The I-7188XC(D) COM Ports can be set as RS-232 or RS-485 as below:

COM Port Type	Pin name
2-wire RS-485	Data+, Data-
3-wire RS-232	TXD, RXD, GND
5-wire RS-232	TXD, RXD, GND, RTS, CTS

The programming required for the 80188 UART is very different from the 16C550. Interrupt handling on the 80188 is also very different from the 8259 on a PC. Therefore, the RS-232 application programs for PC are not executed in the I-7188XC(D).

The software driver for the I-7188XC(D) is an interrupt driven library that provides a 1K QUEUE buffer for each COM Port. The software is well designed and easy to use.

The software driver provides the same interface for all two COM Ports, so each port can be used in the same way without any difficulty.

4.6 Using the COM Ports

 \supset

The 7188XC(D) has two communication ports.

- COM1 can act as either an RS-232 or RS-485 port RS-232: TXD, RXD, RTS, CTS and GND RS-485: DATA+, DATA- (Self-tuner ASIC inside)
- COM2 is an RS-485 port (D2+, D2-, Self-tuner ASIC inside)

Before using the COM Port, the *InstallCom()* (or *InstallCom1/2*) function must be called to install the driver for the COM Port. Before exiting the program, the *RestoreCom()* (or *RestoreCom1/2*) function must be called to uninstall the driver.

After calling the *InstallCom()* function, data can be read from the COM Port, sent to the COM Port, printed from the COM Port and so on.

Before reading data from the COM port, the *IsCom()* function should be used to check if any data has already been sent to the COM Port. If yes, then the *ReadCom()* function should be used to read the data from input buffer of the COM Port.

Before sending data to the COM Port, the *ClearCom()* function could be used to make sure the output buffer of the COM Port is clear, then use the *ToCom()* function to send data to the COM Port.

For example, the code to echo the data back to COM1 (RS-232) is shown below.

int port=1; /*to use COM1*/
int quit=0, data;
InitLib(); /* Initiate the 7188xc library */
InstallCom(port, 115200L, 8, 0, 1); /*install the COM driver*/
while(!quit){
 if(IsCom(port)){ /*check if any data is in the COM Port input buffer*/
 data=ReadCom(port); /*read data from the COM Port*/
 ToCom(port, data); /*send data via the COM Port*/

```
if(data=='q') quit=1; /*if 'q' is received, exit the program*/
}
RestoreCom(port); /*uninstall the COM driver*/
```

Use the "port" variable to switch from COM1 to COM2, simply change **port=1** to **port=2**.

If the program is set to use COM1, the code can be altered as follows:

int quit=0, data; InitLib(); /* Initiate the 7188xc library */ InstallCom1(115200L, 8, 0, 1); /*install the COM1 driver*/ while(!quit){ if(IsCom1()) { /* check if any data is in the COM1 input buffer*/ data=ReadCom1(); /*read data from COM1*/ ToCom1(data); /*send data via COM1*/ if(data=='q') quit=1; /*if 'q' is received, exit the program*/ RestoreCom1(); /*uninstall the COM driver*/

4.6.1 To print from the COM port

The I-7188XC(D) library also supports functions such as *printf()* from the standard C library to produce a formatted output.

The *printCom()* function can be used for all COM Ports, and printCom1/2 can be sued for individual ports. Before using the *printCom()* function, the *InstallCom()* function must first be called. The code is shown below:

int port=2; /*to use COM2*/ int i; InitLib(); /* Initiate the 7188xc library */ InstallCom(port, 115200L, 8, 0, 1); /*install the COM2 driver*/ for(i=0; i<10; i++){ printCom(port, "Test %d\r\n", i); /*print data from COM2*/ } RestoreCom(port); /*uninstall the COM driver*/

4.6.2 To Use COM1/COM2 for an RS-485 Application

COM1/COM2 is a 2-wire RS-485 COM Port, and includes the following 2 pins:

- D+: connect to the Data+ of the RS-485 network
- D-: connect to the Data- of the RS-485 network

COM1/COM2 is a half-duplex 2-wire RS-485 network and cannot be used in a full-duplex 4-wire application. It is designed to directly drive I-7000 series modules.

Send/receive directional control in a 2-wire RS-485 network is very important. Therefore, the I-7188XC(D) is equipped with a Self-Tuner ASIC controller for all RS-485 ports, which will automatically detect and control the send/receive direction of the RS-485 network. In this manner, the application programmer does not have to worry about the send/receive direction control for the RS-485 network.

4.6.3 To Send a Command to an I-7000 module


The commands used for I-7000 series modules are very different from those of the I-7188XC(D), but commands can be sent from the I-7188XC(D) to a I-7000 module using the *ToCom()* function.

Using COM1/COM2 to connect and control I-7000 modules


The procedure for I-7000-related applications is as follows:

- Step 1: The I-7188XC(D) sends a command string to the I-7000 series modules.
- Step 2: The destination I-7000 modules execute the command.
- Step 3: The destination I-7000 modules delay by 1 byte to allow for setting time.
- Step 4: The destination I-7000 modules echo the result string back to the I-7188XC(D).

Note: The delay time used in step 3 is only 1 byte.



The example code for sending a command to COM2 (RS-485) is shown below.



In addition to using the **ToCom()** function, the **SendCmdTo7000()** function can also be used to send commands to an I-7000 series module. The **ReceiveResponseFrom7000()** function can be used to receive the response from an I-7000 series module.

Functions used to connect to an I-7000 module:

SendCmdTo7000(int iPort, unsigned char *cCmd, int iChksum);

This function sends a command to an I-7000 series module. If the checksum is enabled, the function will add 2 bytes checksum to the end of the command.

 ReceiveResponseFrom7000_ms(int iPort, unsigned char *cCmd, long ITimeout, int iChksum);
 After calling the SendCmdTo7000() function the ReceiveResponseFrom7000_ms() function can be called to retrieve a response from an I-7000 series module.

Refer to the demo programs in the CD:\Napdos\7188XABC\7188XC\Demo\BC_TC\7K87K_Module directory for more detailed information.

Note: For more I-7000 commands, please refer to the "**user's manual** for 7000 DIO".

4.7 Using the Red LED and 7-SEG Display

The I-7188XCD includes a 5 digits 7 segment display, together with a decimal point, which can be switched on or off using software. Each digit of the LED is numerically identified from left to right using the numbers 1 to 5, and are individually programmable, which can be very useful in real world applications and can be used to replace a monitor or touch screen in many applications.

Before attempting to use the LED, the *Init5DigitLed()* function must first be called, then the *Show5DigitLed()* function can be used to display data. The code required to display "7188d" on 5 digits 7 segment LED is as follows:

InitLib(); /* Initiate the 7188xc library */ Init5DigitLed(); Show5DigitLed(1, 7); Show5DigitLed(2, 1); Show5DigitLed(3, 8); Show5DigitLed(4, 8); Show5DigitLed(5, 13); /* The ASCII code for 'd' is 13 */

Refer to the demo programs in the CD:\Napdos\7188XABC\7188XC\Demo\BC_TC\LED folder for more information.

4.8 Accessing the I-7188XC(D) Memory 4.8.1 Using Flash Memory

The I-7188XC(D) module contains 256K bytes of Flash memory which includes space reserved for the MiniOS7. The MiniOS7 occupies the 0xF000 segment. So user can use the other segments whose total size is 448K bytes.

Each bit of the Flash memory can only be written from 1 to 0 and cannot be written from 0 to 1. The only way to change the data from 0 to 1 is to call the *EraseFlash()* function to erase a block from the Flash Memory (64K bytes). The user should decide whether to write to the block or to erase it.

To write an integer to segment 0xD000, offset 0x1234 of the Flash Memory, the code is as follows:

```
int data=0xAA55, data2;

char *dataptr;

int *dataptr2;

InitLib(); /* Initiate the 7188xc library */

dataptr=(char *)&data;

FlashWrite(0xd000, 0x1234, *dataptr++);

FlashWrite(0xd000, 0x1235, *dataptr);

/* read data from the Flash Memory method 1 */

dataptr=(char *)&data2;

*dataptr=FlashRead(0xd000, 0x1234);

*(dataptr+1)=FlashRead(0xd000, 0x1235);

/* read data from the Flash memory method 2 */

dataptr2=(int far *)_MK_FP(0xd000, 0x1234);

data=*data
```

Reading data from the Flash Memory is somewhat like reading data from SRAM. The user should allocate a far pointer to point to the memory location first, and then use this pointer to access the memory.

Before writing data to Flash Memory, the user must first call the *FlashWrite()* function, and check whether data can be written or not. After calling the *EraseFlash()* function, data can be written to that segment.

Refer to the demo programs in the

CD:\Napdos\7188XABC\7188XC\Demo\BC_TC\Memory folder for more information.

4.8.2 Using EEPROM

The EEPROM is designed to store data that is not changed frequently, such as:

- Module ID, configuration settings
- COM port configuration settings
- Small databases

The erase/write cycle of the EEPROM is limited to1,000,000 erase/write cycles, so it should not be changed frequently when testing. The EEPROM can be erased/written in a single byte, so it is very useful in real world applications.

The I-7188XC(D) has 2K bytes of EEPROM memory, containing 8 blocks and each block contains 256 bytes, giving a total of 2048 bytes of EEPROM memory. Normally, the EEPROM is in protected mode by default, meaning that no data can be written to the EEPROM. The *EE_WriteEnable()* function must be called to unprotect it before writing any data.

For example: To write data to EEPROM block1, address 10, first call the *EE_WriteEnable()* function . The code is shown below.

ĺ	$\overline{\partial}$	
	int data=0x55, data2;	
	InitLib(); /* Initiate the 7188xc library */ EE_WriteEnable(); EE_MultiWrite(1, 10, 1, &data); EE_WriteProtect();	
	EE_MultiRead(1, 10, 1, &data2); /* now data2=data=0x55 */	

Note: To write an integer to EEPROM, the *EE_WriteEnable()* function must be called twice, in the same manner as writing data to NVRAM.

Refer to the demo programs in the CD:\Napdos\7188XABC\7188XC\Demo\BC_TC\Memory folder for more information.

4.9 Using the Watchdog Timer

The watchdog timer of the I-7188X $\overline{C}(D)$ is fixed at 0.8 seconds for MiniOS7 2.0. When the I-7188XC(D) is first powered on, the watchdog timer will be always enabled. If the watchdog timer is not refreshed within 0.8 seconds, it will reboot the I-7188XC(D).

The MiniOS7 of the I-7188XC(D) will automatically refresh the watchdog after being powered on. User programs can call the software driver to stop the MinOS7 from refreshing the watchdog timer, but the program must then refresh the watchdog timer manually. If the program does not refresh the watchdog timer every 0.8 seconds, it will cause the I-7188XC(D) to reboot.

The program must then ask the MiniOS7 to reset the watchdog timer, then stop and return to the MiniOS7 command prompt.

Use the *EnableWDT()* function to enable the watchdog timer or use the *DisableWDT()* function to disable it. After the watchdog is enabled, the program should call the *RefreshWDT()* function before the timer count reaches 0.8 seconds, otherwise the watchdog will reboot the I-7188XC(D) module. The sample code is as follows:

∂	
InitLib(); /* Initiate the 7188xc library */	
EnableWDT();	
while(!quit)	
{	
RefreshWDT();	
User_function();	
} DisableWDT();	
フ	

The *IsResetByWatchDogTimer()* function is used to check whether the I-7188XC(D) module has been rebooted by the watchdog timer. This function must be inserted at the beginning of program. The sample code is as follows:

main() { InitLib(); /* Initiate the 7188xc library */ if(IsResetByWatchDogTimer()) ł /* do something here to check the system */ } quit=0; EnableWDT(); while(!quit) ł RefreshWDT(); User_function(); }

Refer to the demo programs in the CD:\Napdos\7188XABC\7188XC\Demo\BC_TC\Misc folder for more information.

4.10 Using the Timer Function

The I-7188XC(D) can support one main time tick, 8 StopWatch timers and 8 CountDown timers. The I-7188XC(D) uses a single 16-bit timer to perform these timer functions, with a timer accuracy of 1 ms. The **InstallUserTimer()** function can be used to install a custom timer function and the function will be called at 1 ms intervals. The system timer of the MiniOS7 will call INT 9 every 1 ms and call INT 0x1C every 55 ms. The timer function of the library is linked to associated with called by hooked to INT 9 and will call any custom timer function.

The *TimerOpen()* function is used to start the I-7188XC(D) timer, and this function must be inserted at the beginning of the program. The *TimerClose()* function is used to stop the timer. The sample code is as follows:

```
unsigned long time iTime;

InitLib(); /* Initiate the 7188xc library */

TimerOpen(); /* Begin using the 7188XC timer function */

while(!quit)

{

if(Kbhit())

TimerResetValue(); /* Reset the main time ticks to 0 */

iTime=TimerReadValue(); /* Read main time ticks */

}

TimerClose(); /* Stop using the 7188XC timer function */
```

Refer to the demo programs in the


CD:\Napdos\7188XABC\7188XC\Demo\BC_TC\Timer folder for more information.

4.11 Using Digital Input and Digital output

The I-7188XC(D) provides two DI channels and three DO channels. The **SetDo1High()**, **SetDo1Low()**, **SetDo2High()**, **SetDo2Low()**, **SetDo3High()** and **SetDo3Low()** functions can be used to control the three DO channels, and the **GetDi2()** and **GetDi3()** function can be used to read the states of the two DI channels.

For DI and DO wiring information, please refer to **Section 1.4.6 DI and DO Wire Connection**.

The wiring for a DI/DO application is as follows:



The sample code for retrieving and setting DI and DO is as follows.

```
\partial
 int Do1, Do2, Do3;
 InitLib(); /* Initiate the 7188xc library */
 Print("DI=%s\n\r", GetDi2()?"High":"Low"); /* Read the state of DI2 */
 Print("DI=%s\n\r", GetDi3()?"High":"Low"); /* Read the state of DI3 */
 Do1=GetDo1(); /* Read the state of DO1 */
 Print("DO1=%s\n\r", Do1?"High":"Low");
 if(!Do1)
   SetDo1High(); /* Set the DO1 to ON */
 else
   SetDo1Low(); /* Set the DO1 to OFF */
 Do2=GetDo2(); /* Read the state of DO2 */
 Print("DO2=%s\n\r", Do2?"High":"Low");
 if(!Do2)
   SetDo2High(); /* Set the DO2 to ON */
 else
   SetDo2Low(); /* Set the DO2 to OFF */
 Do3=GetDo3(); /* Read the state of DO3 */
 Print("DO3=%s\n\r", Do3?"High":"Low");
 if(!Do3)
   SetDo3High(); /* Set the DO3 to ON */
 else
   SetDo3Low(); /* Set the DO3 to OFF */
```

Refer to the demo programs in the CD:\Napdos\7188XABC\7188XC\Demo\BC_TC\IO_Pin folder for more information.

4.12 Using the I/O Expansion Bus

As there are many serial interface devices available today, the I/O expansion bus includes both serial and parallel interfaces. The parallel interface is very similar to an ISA bus, so the old ISA bus design can be migrated to the I/O expansion bus with a minimum amount of alteration. The I/O pins of the serial bus are programmable and can be programmed as either D/I or D/O.

The features of these serial devices are as follows:

- Smaller size compared to parallel devices
- Lower cost compared to parallel devices
- Easier to design for isolated applications

The serial interface of the I/O expansion bus makes connecting to these serial devices very easy.

4.12.1 Definition of an I/O Expansion Bus


The I/O expansion bus of the I-7188XC(D) module can be divided into 3 groups as follows:

1. Power supply and reset signals: VCC, GND, RESET and /RESET

2. Parallel Bus:

- System clock: CLOCKA
- Asynchronous ready control: ARDY
- Address bus: A0 ~ A7
- Data bus: D0 ~ D7
- Interrupt control: INT0 and INT1
- Chip select and read/write strobe: /CS, /WR and /RD
- 3. Serial Bus: TO_0, TO_1, TI_0, TI_1, SCLK, DIO9, DIO4 and DIO14

The definition of an I/O expansion bus is given as follows:



J1 pin definition and description:

No	Name	Description
1	GND	PCB ground
2	GND	PCB ground
3	CLOCKA	CPU synchronous clock output
4	ARDY	Asynchronous ready input (level sensitive, OPEN=ready)
5	INT0	Channel 0 interrupt request input (asynchronous, active high)
6	INT1	Channel 1 interrupt request input (asynchronous, active high)
7	VCC	PCB power supply
8	RESET	Power-up reset pulse (active high)
9	GND	PCB ground
10	/RESET	Power up reset pulse (active low)
11	TO_0	CPU Timer output 0(can be used as a programmable D/I/O)
12	TO_1	CPU Timer output 1(can be used as a programmable D/I/O)
13	TI_0	CPU Timer input 0 (can be used as a programmable D/I/O)
14	TI_1	CPU Timer input 1 (can be used as a programmable D/I/O)
15	SCLK	Common serial clock output for 7188 series modules
16	DIO9	Programmable D/I/O bit
17	DIO4	Programmable D/I/O bit
18	DIO14	Programmable D/I/O bit
19	VCC	CPU power supply
20	VCC	CPU power supply

- **CLOCKA:** 20M
- **ARDY:** This pin is left OPEN for applications that do not require the use of wait states
- **INT0 and INT1:** These two pins are left OPEN for that do not require an interrupt applications
- TO_0 and TO_1: These pins can be used as the timer output of the CPU or programmable DI/O
- **TI_0 and TI_1:** These pins can be used as the timer input of the CPU or programmable D/I/O
- DIO4, DIO9 and DIO14: Programmable DI/O bit
- SCLK: The I-7188XC(D) uses this signal as a CLOCK source to drive all onboard serial devices so it is always programmed as DO. Changing this signal to other configurations will cause serious errors. This signal to drive external serial can be used devices without any side effects.

	Name	
	Nume	Description
1	A0	Address bus
2	D0	Data bus
3	A1	Address bus
4	D1	Data bus
5	A2	Address bus
6	D2	Data bus
7	A3	Address bus
8	D3	Data bus
9	A4	Address bus
10	D4	Data bus
11	A5	Address bus
12	D5	Data bus
13	A6	Address bus
14	D6	Data bus
15	N/C	No Connection
16	D7	Data bus
17	N/C	No Connection
18	/WR	Write strobe output (synchronous, active low)
19	/CS	Chip select output (synchronous, active low)
20	/RD	Read strobe output (synchronous, active low)

J2 pin definition and description:

- Address bus (output): A0 ~ A6
- Data Bus (tri-state, bi-direction): D0 ~ D7
- /CS, /RD and /WR: These 3 signals will be synchronous to CLOCKA (Pin3 of JP1) and asynchronous to ARDY (Pin4 of JP1)
- The /CS will be active if the program needs to input/output data from I/O address 0 to 0xff.

Note: The Pin15 and Pin17of JP2 are reserved by I-7188XC(D), user must leave these two pins N/C. For more detailed information, refer to "**I/O Expansion Bus for 7188X/7188E User's Manual**".

4.12.2 Reconfiguring the I-7188XC(D)

There are three DO channels and two DI channels from the pin-4 to pin-8 of the I-7188XC(D). For the application of "Customized 7000 Modules", these 5 pins can be hardware reconfigured to other functions as follows:

Step 1: Remove the reconfiguration-resistor as follows:

- If DO3 is reconfigured, remove R19
- If DO2 is reconfigured, remove R20
- If DO1 is reconfigured, remove R21
- If DI3 is reconfigured, remove R22
- If DI2 is reconfigured, remove R23
- Then, the onboard DI/DO functions can be disabled.
- Step 2: Install a 5-pin male reconfiguration-jumper into the TP0 of the I-7188XC(D)
- Step 3: Design a 5-pin female reconfiguration-jumper in an expansion board for connection to TP1. Then the external signals from pin-4 to pin-8 can be connected to an expansion board. The user can refigure these 5 D/I/O pins to their special requirements now.

Note: If the DO2 is reconfigured to DI, its initial state must be High. If its initial state is Low, system clock will be reduced to 10M. So all clock-related libraries would only be at half-speed.

The X100 is an 8 DI channels board designed for the I-7188XC(D). It removes all 5 resistors, R19 to R23, and reconfigures all these pins as DI pins. It installs another 5-pin female reconfiguration-jumper into TP1 of the I-7188XC(D). Therefore, user can select the original 3_DO_2_DI functions or new 5_DI functions by setting the jumper in different positions. Refer to "I/O Expansion Bus for 7188X/7188E User's Manual" for more detailed information.

4.12.3 I/O Expansion Boards

I/O Expansion Boards for prototyping and testing:

Board	Description
X000	Prototype Board (Small size)
X001	Prototype Board (Large size)
X002	Prototype Board
X003	Self-test

I/O Expansion Boards for DI and DO:

Board	Description
X100	8 DI channels
X101	8 DO channels
X102	2 Relay Output channels
X103	7 DI channels
X104	8 DI channels or 8 DO channels (each channel can be
	programmed to DI/DO)
X105	8 DI channels or 8 DO channels (each channel can be
	programmed to DI/DO)
X106	Can be used as 3 DI channels or 2 DO channels
X400	3 16-bit timer/counter channels

I/O Expansion Boards for A/D, D/A, DI and DO

Board	Description
X200	1 A/D channel (0~2.5V)
X300	2 D/A channels (0~4.095V)
X301	1 A/D channel (0~2.5V) + 1 D/A channel (0~4.095V)
X302	1 A/D channel (+/-5V) + 1 D/A channel (+/-5V)

I/O Expansion Boards for RS-232/422/485, DI and DO

Board	Description
X500	1 9-wire RS-232 channel (Without case)

X501	1 5-wire RS-232 channel
X502	1 3-wire RS-232 channel + 1 5-wire RS-232 channel


I/O Expansion Boards for storage devices:

Board	Descriptions
X600	4M bytes NAND Flash
X601	8M bytes NAND Flash
X607	128K battery backup SRAM
X608	512K battery backup SRAM

Note: Refer to "**I/O Expansion Bus for 7188X/7188E User's Manual**" for more information.

5.Applications

5.1 Embedded Controllers




Applications:

- 4500 replacement and enhancement (not compatible)
- PC-based controller replacement
- PLC replacement
- Special controller replacement

The I-7188XC(D) can be used as an embedded controller for general applications, meaning that it can be used to replace a Host PC, PLC or other special controllers.

Programming Tool	TC/BC/MSC				
Debug Tool	Via standard input/output (keyboard and monitor of a Host PC)				
Man Machine Interface	 MMICON PC keyboard and monitor Touch Screen (RS-232 or RS-485 interface) 				
Program	Stored in Flash Memory				
Input/Output	 Onboard DI or DO From an I/O Expansion Bus 7000 series modules can directly control up to 256 modules giving thousands of I/O points 				

5.2 Local Real Time Controller (RTC)




In this configuration, the 7000 series modules act as slave devices. The control programs are implemented in the Host PC. The operation steps are as follows:

- The PC sends commands to the 7000 series modules and receives some input data.
- The PC analyzes this input data and generates some output data
- The PC sends commands to the 7000 series modules as output data

If there are hundreds of 7000 series modules, it will take the Host PC a long time to analyze and control these modules, so the control program can be implemented in a local I-7188XC(D). The PC then only has to send control arguments to the I-7188XC(D), and the I-7188XC(D) will control the local 7000 series modules based on these control arguments. In this way, thousands of 7000 series modules can be controlled by the PC via the I-7188XC(D).

Some control functions are timing-critical, so the local I-7188XC(D) can handle these functions in real time without the need for control by Host PC.

5.3 Remote Local Controller




In this configuration, the control program is implemented series a local I-7188XC(D). The I-7188XC(D) will directly control the 7000 series modules based on these control arguments.

The Host PC can then access the remote I-7188XC(D) regarding the following items:

- Query and record the status of the remote system
- Download control arguments to the remote I-7188XC(D)

The remote I-7188XC(D) can communicate with the Host PC regarding the following items:

- Emergency event notification and response
- Remote system status notification



Most PLCs contain a Man Machine Interface that was originally designed for MMI applications. The I-7188XC(D) can use this interface to construct a bridge between a PLC and the 7000 series modules.

The I-7188XC(D) can directly read/write from/to the internal memory of the PLC, meaning that the PLC can access the 7000 series input modules as follows:


- The I-7188XC(D) sends a command to the 7000 series input modules
- The I-7188XC(D) writes this data to the internal memory of the PLC
- The PLC accesses this data from its internal memory

The PLC can control the 7000 series output modules as follows:

- The PLC writes data to its internal memory
- The I-7188XC(D) reads the output data from the memory of the PLC
- The I-7188XC(D) sends a command to its 7000 output modules

In this way, the input data from the 7000 series modules can be displayed on a touch screen. In addition the output from the 7000 series modules can be controlled from a touch screen.

5.5 Radio Modem Application



SST-900/SST-2400 settings: (Device A)


- RS-232
- Half-duplex mode
- Synchronous way
- Slave state
- Baud Rate=9600
- Channel=3
- Frequency=915.968MHz

SST-900/SST-2400 settings: (Device B/C/D)

- RS-485 or RS-232
- Half-duplex mode
- Synchronous way
- Slave state

- Baud Rate=9600
- Channel=3
- Frequency=915.968MHz

As the I-7188XC(D) is an embedded controller, and is programmable, it can be used as a bridge between the SST-900 and any external devices, such as a PLC, a controller or other 7000 series modules.



- COM1: The PLC can access the I/O state of the 7000 series modules
- COM2: Directly controls the 7000 series input/output modules
- COM3: MMICON is used as the local MMI
- COM4: The PC is used to monitor and record the system data.

Appendix A: What is MiniOS7

MiniOS7 is an embedded operating system developed by ICP DAS Co., Ltd. that is designed to replace ROM-DOS in 7188 series modules. Various companies have created several brands of DOS. In all cases, DOS (whether PC-DOS, MS-DOS or ROMDOS) is a set of commands or code that tells the computer how to process information. DOS runs programs, manages files, controls information processing, directs input and output, and performs many other related functions.

MiniOS7 provides all equivalent functions of ROM-DOS while, in addition, providing user specific functions for the I-7188XC(D).

	MiniOS7	ROM-DOS
Power-up time	0.1 sec	4 ~ 5 sec
More compact size	<64K bytes	64K bytes
Support for I/O Expansion Bus	Yes	No
Support for ASIC Key	Yes	No
Flash ROM management	Yes	No
O.S. update (download)	Yes	No
Built-in hardware diagnostic functions	Yes	No
Direct control of 7000 series modules	Yes	No
Customer ODM functions	Yes	No
Free of charge	Yes	No

Below is a comparison table between MiniOS7 and ROM-DOS as follows:

Note: ICP DAS reserves the right to change the specifications of MiniOS7 without notice.

Command	Description
LED5 pos value	Displays a HEX value in the specified position of 5-digit LED
USE NVRAM	Accesses the service routine to read/write from/to the NVRAM
USE EEPROM	Accesses the service routine to read/write from/to the EEPROM

The typical command set for MiniOS7

USE FLASH	Accesses the service routine to read/write from/to the Flash Memory				
USE COM2 /option	Accesses the service routine to send/receive to/from COM2				
DATE [mm/dd/yyyy]	Sets the date of the RTC				
Time [hh:mm:ss]	Sets the time of the RTC				
МСВ	Tests the current memory block				
UPLOAD	Stores the MiniOS7 image file in the SRAM of th I-7188XC(D) (this command is only used to upgrad MiniOS7)				
BIOS1Stores the MiniOS7 image file in the Flash memorbios1the I-7188XC(D) (this command only used to upgr MiniOS7)					
LOAD Downloads the user program file to the Flash M of the I-7188XC(D)					
DIR [/crc]	Lists the information of all files stored in the Flash Memory of the I-7188XC(D)				
RUN fileno	Executes the file with the prescribed file number				
Filename	Executes the file with the prescribed file name				
DELETE or DEL	Deletes all files stored in the Flash Memory.				
RESET	Resets the CPU				
DIAG [option]	Performs hardware diagnostics				
BAUD baudrate	Sets a new value for the Baud Rate of COM1				
TYPE filename [/b]	Lists the contents of a file				
REP [/#] command	Repeats the execution of the same command # times				
RESERVE [n]	Reserve n Flash Memory sectors for a program file				
LOADR	Downloads files to the SRAM				
RUNR [option]	Runs the program stored in the SRAM of th I-7188XC(D) (downloaded using the LOADR command				
I/INP/IW/INPW port	Reads data from the hardware Port				
O/OUTP/OW/OUTPW port value Outputs data to the hardware Port					
More					

Note: For more detailed information regarding MiniOS7, please refer to CD:\Napdos\MiniOS7\document\Lib_Manual_For_7188XABC\index.htm or

http://ftp.icpdas.com/pub/cd/8000cd/napdos/minios7/document/lib_man ual_for_7188xabc/index.htm

Appendix B: MiniOS7 Utility and 7188XW

Both the MiniOS7 Utility and 7188xw.exe application will allow users to easily upgrade to the latest version of MiniOS7. The MiniOS7 Utility and 7188xw.exe application can be used to perform essential configuration functions and for downloading programs to the MiniOS7 embedded in the I-7188XC(D) controller.

MiniOS7 Utility

The MiniOS7 Utility program provides three main functions:

- Upgrade the MiniOS7 image
- Download program files to the Flash Memory
- Configure the COM port settings

MiniOS7 utility location

The MiniOS7 utility is located in the CD:\NAPDOS\MINIOS7\UTILITY\MiniOS7_utility folder on the CD or at http://ftp.icpdas.com/pub/cd/8000cd/napdos/minios7/utility/minios7_utility/ on the web

Installation procedure

- Step 1: Locate and execute **minios7_utility_v311.exe** from the **CD:\Napdos\MiniOS7\utility\MiniOS7_utility** folder.
- Step 2: After completing the installation, a new folder, **7188E**, will be added to the **programs** section of the start menu. Clicking on this folder will allow access to the MiniOS7 Utility files. See the diagram below for details.

1 micpdas	🕨 🖬 MiniOS7 Utility Ver 3.11	•	🏄 MiniOS7 Utility Ver 3.11
			👔 MiniOS7 Utility Ver 3.11 Manual
			😽 Uninstall

2 MiniOS7 Utility Verion 3.1.1 (
🗊 File 🌔 Connection - 🚸 Com		guration 📑 Tool	ls 🧼 H	elp 🔻		
Look in: 🛅 MiniOS7_Utility	~	3 🕫 🖻]	Lock in: Disk A	.	8
Name bin FIRMWARE OS_IMAGE icpdas load232.dll MiniOS7_Utility.chm MiniOS7_Utility.exe MiniOS7_Utility.ini uart.dll unins000.dat WiniOS0.exe	File File 1KB 網網 88KB 應用 1,025KB 已編 2,094KB 應用 3KB 組攬 56KB 應用 9KB DA	pe Folder Folder Folder 系網路捷徑 開程式 顧譯的 HTML H 用程式 島設定値 用程式 唐程式擴充 T File 用程式	No	Name	Size	Modified
×		>				
Connection(F2)	Disk Tool(Fl	6) 🛅 Info(F7)	😢 De	lete(F8) 🛃 Refres	h(F9) 🚝 Console(F10)	»

7188XW

The 7188xw.exe application is the main utility for the I-7188XC(D), and can be used to perform the following functions:

- Download user program files from a Host PC into the memory unit of the I-7188XC(D) module.
- Download the MiniOS7 image file from a Host PC into the Flash Memory of the I-7188XC(D) controller and upgrade the MiniOS7.
- Show a debug string on the monitor of a Host PC Three standard output library functions, such as Putch function, Print and Puts, will allow a main control unit to send an output string to the monitor of a Host PC.
- Enter data into I-7188XC(D) module using the Host PC keyboard

Three standard input library functions, such as Getch, Scanf and LineInput, will allow the main control unit to read keyboard input from a Host PC.

7188xw.exe location

The 7188xw.exe is located in the CD:\Napdos\MiniOS7\utility\ folder or at http://ftp.icpdas.com/pub/cd/8000cd/napdos/minios7/utility/ on the web.

Option	Description
/c#	Uses COM# of the Host PC
/b#	Sets the Baud Rate for the COM port on the Host PC (default is 115200)
/s#	Sets the number of display rows on the screen (default is 25, max. is 50)

7188xw.exe command line options for MiniOS7

7188xw.exe Hot-key

Command	Description
F1	Shows the 7188xw.exe help messages
Alt_F1	Shows the 7188xw.exe help messages using the Chinese (Big5) character set
Ctrl_F1	Shows the 7188xw.exe help messages using the Chinese (GB2312) character set
Alt_1	Uses COM1 on the Host PC

F	
Alt_2	Uses COM2 on the Host PC
Alt_3	Uses COM3 on the Host PC
Alt_4	Uses COM4 on the Host PC
Alt_5	Uses COM5 on the Host PC
Alt_6	Uses COM6 on the Host PC
Alt_7	Uses COM7 on the Host PC
Alt_8	Uses COM8 on the Host PC
Alt_9	Uses COM9 on the Host PC
Alt_A	Switches between normal mode and ANSI-Escape-code-support mode
Alt_C	Switches to command mode. Supports commands:
_	b#: Sets a new Baud Rate for the COM ports on the Host PC
	c#: Uses COM# on the Host PC
	n/e/o: Sets the parity to none/even/odd
	5/6/7/8: Sets the data bits to 5/6/7/8
	p#: Sets working directory of the Host PC
	q: Quits command mode
Alt_D	Sets the date of the RTC to the date on the Host PC
Alt_T	Set the time of the RTC to the time on the Host PC
Alt_E	Used to download a file to memory. Alt_E should be pressed only after the "Press ALT_E to download file!" message is shown on the screen.
Alt_H	Toggles between Hex/ASCII display mode
Alt_L	Toggles between normal/line mode. In line mode, all characters pressed will not be sent to the COM Port until the ENTER key is pressed, and it is designed for testing 7000 series modules
Alt_X	Quits the 7188xw.exe application
F2	Sets the file name for downloading (without initiating a download operation)
F5	Runs the program specified by F2 and arguments set by F6
F6	Sets the arguments of the execution file set by F2. (10 arguments maximum. If set to less than 10 arguments, add '*' to end)
Ctrl_F6	Clears the screen
F8	F8=F9+F5
F9	Downloads the file specified by F2 to the FLASH memory
Alt_F9	Downloads all files specified by ALT_F2 to the FLASH memory
F10	Downloads the file specified by F2 to the SRAM and executes it


Alt_F10	Downloads all files specified by ALT_F2 to the SRAM memory
Ctrl_B	Sends a BREAK signal to the COM port of the Host PC that is currently being used by 7188xw.exe
More	

For more detailed information regarding the 7188xw.exe application, please refer to the index.htm file in the


CD:\Napdos\MiniOS7\document\Lib_Manual_For_7188XABC\ folder or at http://ftp.icpdas.com.tw/pub/cd/8000cd/napdos/minios7/document/lib_manual_for_7188xabc/ on the web.

Downloading a file to the I-7188XC(D) controller using the 7188xw.exe application


Step 1: Power-off the I-7188XC(D). Connect the INIT* pin to the GND pin and power-on the I-7188XC(D) at the same time.



- Step 2: After the I-7188XC(D) has been switched on, disconnect the INIT* pin from the GND pin.
- Step 3: Open an MS-DOS command prompt window using the steps shown bellow.



Step 4: Type "cd c:\7188XC\Demo\BC_TC\Hello\Hello_C\" then press <**Enter**>. (Assume user copy the 7188XC folder to C drive letter. Refer to Step2 in Sec.2.1)



Step 5: Execute the **7188xw.exe** application as shown in the following figure.

▼ 7188XW 1.32 [COM1:115200,N,8,1],FC=0,CTS=0, DIR=C:\7188XC\Demo\BC_TC\Hello\Hello_C
C:\7188XC\Demo\BC_TC\Hello\Hello_C>7188xw
<pre>7188x for WIN32 version 1.32 (2006/10/17)[By ICPDAS. Tim Tsai.] [Begin Key Thread] Current set: Use COM1 115200,N,8,1 AutoRun: Autodownload files: None Current work directory="C:\7188XC\Demo\BC_TC\Hello\Hello_C" original baudrate = 115200!</pre>
now baudrate = 115200! -

Step 6: Press **<F2**> and then type the filename "**Hello.exe**" and press **<Enter**>.

```
C:\7188XW 1.32 [COM1:115200,N,8,1],FC=0,CTS=0, DIR=C:V188XC\Demo\BC_TC\Hello\Hello_C
C:\7188XC\Demo\BC_TC\Hello\Hello_C>7188xW
7188x for WIN32 version 1.32 (2006/10/17) [By ICPDAS. Tim Tsai.]
[Begin Key Thread...]
Current set: Use COM1 115200,N,8,1
AutoRun:
Autodownload files: None
Current work directory="C:\7188XC\Demo\BC_TC\Hello\Hello_C"
original baudrate = 115200!
now baudrate = 115200!
i7188XC>
Input filename:Hello.exe
When Press F8/F9/F10 will auto download the file:Hello.exe
```

Step 7: Press <**F8**> to download the Hello.exe file to the I-7188XC(D) and execute the program.

7188XW 1.32 [COM1:115200,N,8,1],FC=0,CTS=1, DIR=C:\7188XC\Demo\BC_TC\Hello\Hello_C	- 🗆 🗙
Input filename:Hello.exe When Press F8/F9/F10 will auto download the file:Hello.exe [F8]LOAD File will save to 81BC:000B StartAddr>8000:1BCA Press ALT_E to download file! Load file:Hello.exe[crc=1ED6,0000] Send file info. total 28 blocks Block 28 Transfer time is: 2.250000 seconds i7188XC>Hello.exe Hello world!	
i7188xc>_	

Notes: A description of the Hotkey functions is as follows:


F8: Download a file to FLASH Memory, and then execute the program F9: Download a file to FLASH Memory.

F10: Download a file to SRAM, and then execute the program.

Step 8: Type "dir" and press <**Enter**> to check that the files are stored in the Flash Memory of the I-7188XC(D).



Step 9: Type "**del /y**" and press <**Enter**> to delete all files stored in the Flash Memory of the I-7188XC(D).



Note: The MiniOS7 only supports the **delete all** command. Individual files cannot be selected for deletion.

Step 10: Press <**Alt + X**> to quit the MiniOS7.

Upgrading MiniOS7 using the 7188xw.exe application


- Step 1: Connect the I-7188XC(D) to the COM Port of the Host PC using the CA0910 cable. Refer to the wiring diagram in Section 2.2 for details.
- Step 2: Determine the latest version of the MiniOS7 image file. The format of the image file name is: **TTYYMMDD.img TT**: TYPE of product.
 - **YY**: Year that this image was released
 - **MM**: Month that this image was released

DD: Day that this image was released


Note: The MiniOS7 image file can be found in the CD:\NAPDOS\MiniO7\ directory on the companion CD. The latest MiniOS7 version can be downloaded from:

http://ftp.icpdas.com/pub/cd/8000cd/napdos/7188xabc/7188xc/os_image/


- Step 3: From the Host PC, go to the directory where the image file is stored, then execute the 7188xw.exe application to connect the Host PC to the I-7188XC(D) controller.
- Step 4: Use the "**UPLOAD**" command, then press <**ALT + E**> after the "Press ALT_E to download file!" message is shown on the screen.



- Step 6: Wait for the upload to finish. (The image file will be stored in the SRAM.)
- Step 7: Type the "**bios1**" command in the I-7188XC(D) command line. (The OS will check the image file stored in the SRAM, and then display the version information. If the image file is correct, it will be written to the Flash Memory.)



Step 8: It will take about 10 seconds to upgrade MiniOS7. After the update has finished, the system will automatically reboot. If this does not occur, the system must be rebooted manually.



Step 9: Type the "ver" command to check the MiniOS7 version number.

T188XW 1.32 [COM1:115200,N,8,1],FC=0,CTS=0, DIR=C:\7188XC\OS_image	- 🗆 🗙
17188XC>ver	
ICP_DAS MiniOS7 for I-7188XC Ver. 2.00 build 002,Jun 28 2005 14: SRAM:128K, FLASH MEMORY:512K [CPU=RDC 8820-D] CPU internal WDT is ENABLED(WDT timeout=0.8 sec)	50:52
i7188XC>	- 1


Appendix C: Comparison Table

Feature comparison table between the 7188 and the 7188X series:

•	I-7188XA(D)	I-7188XB(D)	I-7188XC(D)	I-7188(D)
CPU clock	80188, 40MHz	80188, 40MHz	80188, 20MHz	80188, 40MHz
SRAM	512K	256K(I-7188XB) 512K(I-7188XB/512)	128K	256K
Flash Memory	512K	512K	256K (512K for ODM)	256K/512K
COM1	RS-232 with modem control or RS-485 with internal self-tuner	RS-232 or RS-485 with internal self-tuner	RS-232 or RS-485 with internal self-tuner	RS-232 with modem control or RS-485
COM2	RS-485 with internal self-tuner, 3000V isolation	RS-485 with self-tuner inside	RS-485 with self-tuner inside	RS-485
COM3	RS-232 (TxD, RxD)	No COM	No COM	RS-232 (TxD, RxD)
COM4	RS-232 (Txd, Rxd)	No COM	No COM	RS-232 (TxD, RxD)
User defined pins	0	14	3	0
Modem control	COM1	No	No	COM1
RTC	Yes	Yes	No	Yes
64-bit hardware unique serial number	Yes	Yes	No	No
EEPROM	2K bytes	2K bytes	2K bytes	2K bytes
D/I (3.5V~30V)	2 channels	1 channel	2 channels	0
D/O (100mA, 30V)	2 channels	1 channel	3 channels	0
I/O expansion bus	Yes	Yes	Yes	No
Support for ASIC Key	Yes	Yes	Yes	No
Operating system	MiniOS7	MiniOS7	MiniOS7	MiniOS7
Programming language	TC/MSC/BC	TC/MSC/BC	TC/MSC/BC	TC/MSC/BC
Program download Port	COM4	COM1	COM1	COM4

Appendix D: Library Function List

The table below lists the most commonly used functions. For more details of all functions, refer to the instructions in the CD:\Napdos\MiniOS7\document\Lib_Manual_For_7188XABC\index_e.htm file or http://ftp.icpdas.com/pub/cd/8000cd/napdos/minios7/document/lib_man ual for 7188xabc/index e.htm on the web.



Type 1: Standard IO

Function	Description
Kbhit	Checks if any keyboard input data is currently available in the input buffer of COM1.
Getch	Waits until a single character is received from keyboard input.
Ungetch	Returns a single character to the input buffer of COM1.
Putch	Sends a single character to COM1.
Puts	Sends a string to COM1.
Scanf	Retrieves formatted data such as scanf in the C language (Cannot used on MSC/VC++, only TC/BC)
Print	Prints formatted data such as printf in the C language.
ReadInitPin	Reads the status of the INIT* pin.
LineInput	Inputs a single line from StdInput.
More	There are more user functions for Standard IO. For more detailed information, please refer to the 7188xc.h file and CD:\Napdos\MiniOS7\document\Lib_Manual_For_7188XABC\index.htm

Note: The **Print** and **printCom** function cannot be used simultaneously in the same program.

```
• Kbhit()
               Checks whether any keyboard input data is currently
  Function:
               available in the input buffer.
               int Kbhit(void);
  Syntax:
  Header:
               #include "7188xc.h"
  Description: Checks if any data is currently available in the input
               buffer.
               0: For no data input.
  Return:
               Other: There is data in the input buffer, and the return
                      value is the next data in the buffer. If the next data
                      is "\0", the function will return -1 (0xFFFF).
  Example:
  #include "7188xc.h"
  void main()
  {
    int quit=0, data;
    InitLib();
    Puts("\n\rPress any key to show ASCII ('Q' to guit):\n\r");
    while(!quit){
      if(Kbhit()){
        data=Getch();
        if(data=='Q') quit=1;
        Putch(data);
        Print(" ASCII is: %d\n\r", data);
        Puts("\n\rPress any key to show ASCII ('Q' to guit):\n\r");
      }
    }
  }
Getch()
```

Function: Waits until a character is received from keyboard input.Syntax: int Getch(void);

Header: #include "7188xc.h"

Description: Reads a single character from the input buffer. If there is no input in the data buffer, the function will wait until the input buffer receives some data.

Return Value: 0 to 255.

Example: Please refer to "Kbhit()" for an example.

• Ungetch()

Function:	Put a single character to the input buffer.
Syntax:	int Ungetch(int data);
Header:	#include "7188xc.h"
Descriptior	n: If there is no data in the input buffer when Ungetch() is
	called, next time the Getch() function is called, it will
	return the data.
	Data: 0 to 255. If the data is > 255, only the low byte will
	be sent.
Return:	On success, returns NoError. On error (i.e. the buffer is
	full) returns 1.
Example:	Please refer to "Kbhit()" for an example of Getch().

• Putch()

Displays a single character on the screen.
void Putch(int data);
#include "7188xc.h"
: Data: 0 to 255. If the data is > 255, only the low byte will
be sent.
Please refer to "Kbhit()" for an example.

• Puts()

v			
Function:	Displays a string on the screen.		
Syntax:	void Puts(char *str);		
Header:	#include "7188xc.h"		
Description: Puts will call Putch() to send the string.			
	str: The pointer to the string to be sent.		
Example:	Please refer to "Kbhit()" for an example.		

• Scanf()

Function: Scans a character from the input and is similar to the scanf() function. (This function cannot be used with MSC /VC++)

Syntax: int Scanf(char *fmt, ...);

Header: #include "7188xc.h"

Description: Returns the number of input fields successfully scanned,

converted, and stored. The return value does not include any scanned fields that were not stored.

Return: 0: No fields were stored. EOF: Attempts to read have reached the end of the string.

Example: See CD:\Napdos\7188XABC\7188XC\Demo\MSC\COM_ Ports\C_Style_IO\

• Print()

Function: Prints a formatted character to the screen, and is similar to the printf() function in the C language.

Syntax: int Print(char *fmt,...);

Header: #include "7188xc.h"

Description: This function is used instead of printf(), and the only difference between Print() and printf() is that Print() does not convert the characters "\n" to "\n" + "\r". That is "\n" only sends the code 0x0A, not 0x0A + 0x0D, so "\n\r" has to be used for "new line and return". The printed message is sent to COM4. (Default parameters are 115200, N, 8, 1)

Input Parameters: Please refer to the standard function printf() in the C language.

- Return: The character number to be sent out.
- Example: Please refer to "Kbhit()" for an example.

Type 2: COM port

Function	Description
InstallCom	Installs the COM Port driver. The COM Port number is not assigned
InstallCom1	Installs the driver for COM1
InstallCom2	Installs the driver for COM2
RestallCom	Uninstalls the drivers for the COM Port. The COM Port number is not assigned
RestallCom1	Uninstalls the driver for COM1. Assigned to COM1 RestallCom2 and etc are similar
IsCom	Check if Com has data. The COM Port number is not assigned
IsCom1	Checks if any data is waiting in the COM1 buffer
IsCom2	Checks if any data is waiting in the COM2 buffer
ClearCom	Clears all the data currently stored in the COM Port Buffer. The COM Port number is not assigned
ClearCom1	Clears all the data currently stored in the COM1 buffer
ClearCom2	Clears all the data currently stored in the COM2 buffer
ReadCom	Reads the data from COM Port buffer. The COM Port number is not assigned
ReadCom1	Reads data from the COM1 buffer
ReadCom2	Reads data from the COM2 buffer
ToCom	Sends data to the COM Port. The COM Port number is not assigned
ToCom1	Sends data to the COM1
ToCom2	Sends data to the COM2
printCom	Prints any data currently stored in the COM Port buffer. The COM Port number is not assigned
printCom1	Prints any data currently stored in the COM1
printCom2	Prints any data currently stored in the COM2
More	There are more functions available for use with COM Ports. Please refer to the 7188xc.h file and CD:\Napdos\MiniOS7\document\Lib_Manual_For_7188XABC\index.htm

Note: The **Print** and **printCom** function cannot be used simultaneously in the same program.

```
InstallCom()
              Installs the driver for the COM Port.
  Function:
  Syntax:
              int InstallCom(int port, unsigned long baud, int data,
              int parity, int stop);
              #include "7188xc.h"
  Header:
  Description: Installs the driver for the COM Port. The COM Port
               number is not assigned and can be modified using the
               "port" parameter.
               port: assigns the COM port number
               baud: Baud Rate, the default Baud Rate for the
               I-7188XC(D) is 115200
  Example:
  #include "7188xc.h"
  void main()
  {
    int quit=0, data, i, port=1; /*port=1, uses COM1*/
    InitLib();
    InstallCom(port,115200,8,0,1); /*installs the COM port driver*/
    for(i=0; i<10; i++)
      printCom(port, "Test %d\n\r",i); /*prints data to the COM Port*/
    while(!quit) {
      if(IsCom(port)) { /*checks if any data is in the COM Port buffer*/
        data=ReadCom(port); /*reads data from the COM Port buffer*/
        ToCom(port,data); /*sends data to the COM Port buffer*/
        ClearCom(port); /*clears all the data in the COM Port buffer*/
        if(data='Q') quit=1; /*if 'Q' is received, exit the program*/
      }
    }
    RestoreCom(port); /*uninstalls the driver for COM Port */
  }
```

InstallCom1()

Function: Installs the driver for COM1.

Syntax: int InstallCom1(unsigned long baud, int data, int parity, int stop);

Header: #include "7188xc.h"

Description: Installs the driver for COM1, and is assigned to COM1 baud: Baud Rate, the default Baud Rate for the I-7188XC(D) is 115200

Example:

```
#include "7188xc.h"
void main()
{
    int quit=0,data;
    InitLib();
    InstallCom1(115200,8,0,1); /*install the driver for COM1*/
    while(!quit) {
        if(IsCom1()) { /*checks if any data is in the COM1 buffer*/
            data=ReadCom1(); /*reads data from COM1*/
            ToCom1(data); /*sends data to COM1*/
            if(data='q') quit=1; /*if 'q' is received, exit the program*/
        }
        RestoreCom1(); /*uninstalls the driver for COM1*/
}
```

• RestoreCom()

Function: Uninstalls the driver for the COM Port. The COM Port number is not assigned.

Syntax: int RestoreCom(int port);

Header: #include "7188xc.h"

Description: Uninstalls the driver for the COM Port. The COM Port number is not assigned and can be modified using the "port" parameter.

port: assigns the COM Port number

Example: Please refer to "InstallCom()" for an example.

RestoreCom1()

Function: Uninstall the driver for COM1.
Syntax: int RestoreCom1(void);
Header: #include "7188xc.h"
Description: Uninstall the driver for COM1 and is assigned to COM1
Example: Please refer to "InstallCom1()" for an example.

• IsCom()

Function: Checks whether there is any data stored in the COM Port buffer. The COM Port number is not assigned.
 Syntax: int IsCom(int port);

Header: #include "7188xc.h"

Description: Checks whether there is any data stored in the COM Port buffer. The COM Port number is not assigned and can be modified using the "port" parameter. port: assigns the COM port number

Example: Please refer to "InstallCom()" for an example.

IsCom1()

Function: Checks whether there is any data stored in the buffer of COM1.

Syntax int IsCom1(void);

Header: #include "7188xc.h"

Description: Checks whether there is any data stored in the buffer of COM1

Example: Please refer to "InstallCom1()" for an example.

• ReadCom()

Function: Reads data from the COM Port buffer. The COM Port number is not assigned.

Syntax: int ReadCom(int port);

Header: #include "7188xc.h"

Description: Reads data from the COM Port buffer. The COM Port number is not assigned and can be modified using the "port" parameter.

port: assigns the COM Port number

Example: Please refer to "InstallCom()" for an example.

ReadCom1()

Function: Reads data from the buffer of COM1.

Syntax: int ReadCom1(void);

Header: #include "7188xc.h"

Description: Reads data from the buffer of COM1. Assigned to COM1.

Example: Please refer to "InstallCom1()" for an example.

• ClearCom()

Function: Clears the data currently stored in the COM Port buffer. The COM Port number is not assigned.

Syntax: int ClearCom(int port);

Header: #include "7188xc.h"

Description: Clears the data currently stores in the COM Port buffer. The COM Port number is not assigned and can be modified using the "port" parameter.

port: assigns the COM Port number

Example: Please refer to "InstallCom()" for an example.

• ClearCom1()

Function: Clears the data currently stored in the buffer of COM1. Syntax: int ClearCom1(void);

Header: #include "7188xc.h"

Description: Clears the data currently stored in buffer of COM1. Assigned to COM1.

Example: Please refer to "InstallCom1()" for an example.

• ToCom()

Function: Sends data to the COM Port. The COM Port number is not assigned.

Syntax: int ToCom(int port);

Header: #include "7188xc.h"

Description: Sends data to the COM Port. The COM Port number is not assigned and can be modified using the "port" parameter.

port: assigns the COM Port number

Example: Please refer to "InstallCom()" for an example.

• ToCom1()

Function: Sends data to COM1.
Syntax: int ToCom1(void);
Header: #include "7188xc.h"
Description: Sends data to COM1. Assigned to COM1.
Example: Please refer to "InstallCom1()" for an example.

• printCom()

Function: Prints data to COM and PC. The COM Port number is not assigned.

Syntax: int printCom(int port,char *fmt,...);

Header: #include "7188xc.h"

Description: Prints data from the COM Port buffer. The COM Port number is not assigned and can be modified using the "port" parameter. Produces a formatted output, similar to printf() from the standard C library.

Example: Please refer to "InstallCom()" for an example.

• printCom1()

Function: Prints data from the buffer of COM1.

Syntax: int printCom_1(char *fmt,...);

Header: #include "7188xc.h"

- Description: Prints data from the buffer of COM1. Produces a formatted output, similar to printf() from standard C library.
- Example: This function is similar to printCom(). Please refer to "InstallCom()" for an example.

Type 3: EEPROM

Function	Description				
EE_WriteEnable	Sets the EEPROM to write-enable mode				
EE_MultiWrite	Writes data to the EEPROM				
EE_WriteProtect	Sets the EEPROM to write-protect mode				
EE_MultiRead Reads data from the EEPROM					
More	There are many other user functions related to EEPROM. Please refer to the 7188xc.h header file and the user manual on the enclosed CD, which can be found at CD:\Napdos\MiniOS7\document\Lib_Manual_For_7188XABC\ind ex.htm for more detailed information.				

• EE_WriteEnable ()

Function: Sets the EEPROM to write-enable mode.

Syntax: void EE_WriteEnable (void);

Header: #include "7188xc.h"

Description: Sets the EEPROM to write-enable mode. The EEPROM is in write-protect mode by default. EE_WriteEnable() must be called before writing data to the EEPROM.

Example:

#include <7188xc.h> void main() { Int data=55, data2; InitLib(); EE_WriteEnable (); EE_MultiWrite(1,10,1,&data); EE_MultiRead(1,10,1,&data2); Print("data=%d, Data2=%d", data,data2); }

}

• EE_MultiWrite ()

Function: Writes data to the EEPROM

Syntax: int EE_MultiWrite(int Block,unsigned Addr,int no,char *Data);

Header: #include "7188xc.h"

Description: Writes multi-byte of data to the EEPROM.

Block: 0 to 7 (a total of 8 blocks).

Addr: 0 to 255 (each block can contain 256 bytes). no: 1 to 16

Data: The start address of buffer that the data is stored. Return Value: On success, returns NoError.

On error, returns -1. It is say EEPROM is busy, Block is invalid or Addr is invalid.

Example: Please refer to "EE_WriteEnable()" for an example.

• EE_WriteProtect ()

Function:Sets the EEPROM to write-protect modeSyntax:void EE_WriteProtect(void);Header:#include "7188xc.h"Description:Sets the EEPROM to write-protect mode. The EEPROM

is in write-protect mode by default. EE_WriteEnable() must be called before writing data to the EEPROM. After writing the data, it is recommended that EE_WriteProtect () be called to return the EEPROM to write-protect mode.

Example: Please refer to "EE_WriteEnable()" for an example.

• EE_MultiRead ()

Function: Reads data from the EEPROM

Syntax: int EE_MultiRead(int StartBlock,unsigned StartAddr,int no,char *databuf);

Header: #include "7188xc.h"

Description: Reads multi-byte data from the EEPROM.

StartBlock: 0 to 7 (a total of 8 blocks).

StartAddr: 0 to 255 (each block can contain 256 bytes). no: 1 to 2048

databuf: The address to store data

Return Value: On success, returns NoError.

On error, returns -1. It is say EEPROM is busy, Block is invalid or Addr is invalid.

Example: Please refer to "EE_WriteEnable()" for an example.

Type 4: NVRAM and RTC

Function	Description
ReadNVRAM	Reads data from the NVRAM.
WriteNVRAM	Writes data to the NVRAM.
GetTime	Gets the system time from the RTC.
SetTime	Sets the system time for the RTC
GetDate	Gets the system date from the RTC
SetDate	Sets the system date for the RTC
GetWeekDay	Gets the day of the week from the RTC.
More	There are many other functions related to the NVRAM and the RTC. Please refer to the 7188xc.h header file and the user manual on the enclosed CD, which can be found at CD:\Napdos\minios7\document\lib_manual_for_7188xabc\index.htm for more detailed information.

ReadNVRAM()

Function: Reads data from the NVRAM.

Syntax: int ReadNVRAM(int addr);

Header: #include "7188xc.h"

Description: Reads one byte of data from the NVRAM.

addr: 0 to 30, a total of 31 bytes.

Return Value: On success, returns the data (0-255) stored at the specified address.

On error, returns the AddrError (-9).

Example:

#include "7188xc.h"

```
void main()
```

{

```
int data=55, data2;
InitLib();
WriteNVRAM(0,data);
data2=ReadNVRAM(0); /* now data2=data=55 */
Print("data=%d, data2=%d",data,data2);
```

}

• WriteNVRAM()

Function: Writes data to the NVRAM. Syntax: int WriteNVRAM(int addr, int data); Header: #include "7188xc.h"

Description: Writes one byte of data to the NVRAM.

addr: 0-30.

```
data: One byte of data (0-255).
```

If the data>255, only the low byte will be written to the NVRAM.

Return Value: On success, returns NoError.

On error, returns the AddrError (-9).

Example: Please refer to "ReadNVRAM()" for more detailed information.

GetTime()

Function: Retrieves the system time from the RTC. Syntax: void GetTime(int *hour, int *minute, int *sec); #include "7188xc.h" Header: Description: hour: The address used to save the hour (0-23) data. minute: The address used to save the minute (0-59) data. sec: The address used to save the second (0-59) data. Example: #include "7188xc.h" void main() { int year, month, day, hour, min, sec, wday; InitLib(); SetDate(2006,1,12); /*sets the system date for the RTC*/ SetTime(15,35,50); /*sets the system time for the RTC*/ SetWeekDay(4); /*sets the system day of the week for the RTC*/ GetDate(&year,&month,&day); /*reads the system date from the RTC*/ GetTime(&hour,&min,&sec); /*reads the system time from the RTC*/ wday=GetWeekDay(); Print("Date=%02d/%02d/%04d(%d) Time=%02d:%02d:%02d\n\r", month.day,year,wday,hour,min,sec); }

• SetTime()

Function:	Sets the system time to the RTC
Syntax:	<pre>int SetTime(int hour,int minute,int sec);</pre>
Header:	#include "7188xc.h"

Description: hour: 0-23. minute: 0-59. sec: 0-59. Return Value: On success, returns NoError. On error, returns the TimeError (-19). Example: Please refer to "GetTime()" for more detailed information.

GetDate()

• SetDate()

Function:	Sets the system date to the RTC
Syntax:	int SetDate(int year,int month,int day);
Header:	#include "7188xc.h"
Descriptior	n: year: 2000-2080
	month: 1-12
	day: 1-31
Return Val	ue: On success, returns NoError.
	On error, returns DateError (-18).
Example:	Please refer to "GetTime()" for more detailed information.

• GetWeekDay()

Function: Reads the weekday from the RTC.
Syntax: int GetWeekDay(void);
Header: #include "7188xc.h"
Description: Reads the weekday from the RTC.
Return Value: 0=>Sunday

1-6=>Monday to Saturday.

Example: Please refer to "GetTime()" for more detailed information.

Note: GetWeekDay() does not check whether the weekday is correct or not, only reads the value from the RTC. When using the MiniOS7

"date" command to set the date, the MiniOS7 will calculate the correct weekday and set the RTC. If SetDate() is called, it will also calculate the correct weekday and set the RTC. However, if SetWeekDay() is called, the function must calculate the correct weekday itself.

Type 5: Flash Memory

Function	Description						
FlashReadId	Retrieces the information about Flash.						
FlashErase	Erases a single sector of the Flash memory.						
FlashWrite	Writes one byte of data to the Flash memory.						
FlashRead	Reads one byte of data from the Flash memory.						
More	There are many other functions related to the Flash memory. Please refer to the 7188xc.h header file and the user manual on the enclosed CD, which can be found at CD:\Napdos\minios7\document\lib_manual_for_7188xabc\index.htm for more detailed information.						

The Flash memory used in I-7188XC(D) series modules has a capacity of 256K bytes. The MiniOS7 will use the last 64K bytes, and the remaining space can be used to store custom programs or data.

Application developers can use these functions to write data to the Flash memory. When writing data to the Flash memory, data only be written from "1" to "0", and cannot be written from "0" to "1". So, before writing data to the Flash memory, must be erased first. The erase process will cause all data to revert to 0xFF, that is all data bits will be "1". Only then can data be written. The FlashErase() function is used to erase one sector (64K bytes) each time.

• FlashReadId()

Function: Rétrieves the information about Flash.
Syntax: int FlashReadId(void);
Header: #include "7188xc.h"
Description: Reads the Flash memory device code (high byte) and manufacturer code (low byte).
Return Value: 0xA4C2 (MXIC 29f040), 0xA401 (AMD 29f040)
Example: See CD:\Napdos\7188XABC\7188XC\Demo\BC_TC\ Memory\

FlashErase()

Function:Erases a single sector of the Flash memory.Syntax:int FlashErase(unsigned seg);

Header: #include "7188xc.h"

Description: Erases a single sector (64K bytes) of the Flash memory. The value of all data on that sector will revert to 0xFF. seg: 0xC000, 0xD000 or 0xE000.

Return Value: On success, returns NoError (0). On error, returns TimeOut (-5).

Example: Please refer to "\Demo\BC_TC\Memory\Flash\ FLASH.C" for more detailed information.

Note: Segment 0xF000 is used to store the MiniOS7, if attempting to erase segment 0xF000, FlashErase() will do nothing.

• FlashWrite()

Function: Writes one byte of data to Flash memory. int FlashWrite(unsigned int seg, unsigned int offset, Syntax: char data): #include "7188xc.h" Header: Description: seg: 0xC000, 0xD000 or 0xE000. offset: 0 to 65535 (0xffff). data: 0 to 255 (8-bit data). Return Value: On success, returns NoError(0). On error, returns TimeOut(-5) or SegmentError(-12). Example: #include "7188xc.h" void main() { int data=0xAA55, data2; char *dataptr; InitLib(); dataptr=(char *)&data; FlashWrite(0xd000,0x1234, *dataptr++); /*writes data to the Flash *memory*/* FlashWrite(0xd000,0x1235, *dataptr); dataptr=(char *)&data2; /*reads data from the Flash memory*/ *dataptr=FlashRead(0xd000, 0x1234); *(dataptr+1)=FlashRead(0xd000, 0x1235); }

Note: When writing data to the Flash memory, the data bit only can

be changed from 1 to 0 and cannot be written from "0" to "1". FlashWrite() does not check the status, and just writes the data. If an attempt is made to change the data from 0 to 1, a TimeoutError will occur. After calling FlashErase() data can be written again.

FlashRead()

information.

Function: Reads one byte of data from the Flash memory.
Syntax: int FlashRead(unsigned int seg, unsigned int offset);
Header: #include "7188xc.h"
Description: seg: 0xC000, 0xD000 or 0xE000. offset: 0 to 65535(0xffff).
Return Value: FlashRead() only returns the value of the address. seg: offset. The address can be from the SRAM, the Flash memory or another address (generally returns 0xff).
Example: Please refer to "FlashWrite()" function for more detailed

Function	Description				
TimerOpen	Opens the timer function for use.				
TimerClose	Stops the timer function.				
TimerResetValue	Resets the timer to 0.				
TimerReadValue	Reads the main time ticks.				
DelayMs	Inserts a delay for a specific time interval. The time unit is ms, and uses system time ticks.				
Delay	Inserts a delay for a specific time interval. The time unit is ms, and uses the Timer 1 feature of the CPU.				
Delay_1	Inserts a delay for a specific time interval. The time unit is 0.1 ms, and uses the Timer 1 feature of the CPU.				
Delay_2	Inserts a delay for a specific time interval. The time unit is 0.01 ms, and uses the Timer 1 feature of the CPU.				
StopWatchStart	Starts using a StopWatch channel.				
StopWatchReset	Resets the StopWatch value to 0.				
StopWatchStop Disables the StopWatch channel.					
StopWatchPause	Pauses the StopWatch.				
StopWatchContinue	Restarts the StopWatch.				
StopWatchReadValue	Reads the current StopWatch value.				
CountDownTimerStart	Starts using CountDownTimer.				
CountDownTimerReadValue	Reads the current CountDownTimer value				
InstallUserTimer	Installs a user timer function, which will be called at intervals of 1 ms.				
InstallUserTimer1C	Installs a user timer function on interrupt 0x1c. System timer will call int 0x1c at intervals of 55 ms.				
EnableWDT	Enables the Watchdog timer				
DisableWDT	Disables the Watchdog timer				
RefreshWDT	Refreshes the Watchdog timer				
More	There are many other custom timer and Watchdog Timer functions available. Please refer to the 7188xc.h header file				

Type 6: Timer and Watchdog Timer

and the user manual on the enclosed CD,
which can be found at
CD:\Napdos\minios7\document\lib_manual_for_
7188xabc\index.htm for more detailed
information.

• TimerOpen()

```
Function: Opens the timer function for use.
Syntax:
            int TimerOpen(void);
            #include "7188xc.h"
Header:
Description: Before any of the timer functions can be used the
             TimerOpen() function must be called.
Return Value: On success, returns NoError. If the Timer is already
               open, returns 1.
Example:
#include "7188xc.h"
void main()
{
  unsigned long time;
  int quit=0;
  InitLib();
  Print("\n\rPress any key to start the timer");
  Print("\n\rthen Press '0' to Reset the timer, '1'~'4' to insert a delay, 'q' to
           quit\n\r");
  Getch():
  TimerOpen(); /*open the timer function*/
  while(!quit){ /*sets the key function*/
    if(Kbhit()){
      switch(Getch()){
        case '0':
          TimerResetValue(); /*reset the timer*/
          break:
        case '1':
          DelayMs(1000); /*delay unit is ms, uses system timeticks. */
          break:
        case '2':
          Delay(1000); /*delay unit is ms, uses the Timer 1 feature of the
                            CPU. */
          break;
        case '3':
          Delay_1(1000); /*delay unit is 0.1 ms, uses the Timer 1 feature
```

```
of the CPU.*/
break;
case '4':
Delay_2(1000); /*delay unit is 0.01 ms, uses the Timer 1
feature of the CPU .*/
break;
case 'q':
quit=1;
break;
}
time=TimerReadValue(); /*reads the timer*/
Print("\r\nTime=%8.3f sec", 0.001*time);
}
TimerClose(); /*closes the timer function*/
}
```

• TimerClose()

Function: Stops the timer function.

Syntax: int TimerClose(void);

Header: #include "7188xc.h"

Description: If the program has called the OpenTimer() function, it must call TimerClose() before exiting.

Return Value: Always returns NoError.

Example: Please refer to "TimerOpen()" function for more detailed information.

• TimerResetValue()

Function: Resets the timer to 0.

Syntax: void TimerResetValue(void);

Header: #include "7188xc.h"

Description: Resets the main time ticks to 0.

Example: Please refer to "TimerOpen()" function for more detailed information.

• TimerReadValue()

Function: Reads the main time ticks.
Syntax: unsigned long TimerReadValue(void);
Header: #include "7188xc.h"
Description: Reads the main time ticks. The time unit is ms. When

TimerOpen or TimerReset are called, the time ticks will be reverted to 0.

Example: Please refer to "TimerOpen()" function for more detailed information.

• DelayMs()

Function: Inserts a delay for a specific time interval. The time unit is ms and uses system time ticks.

Syntax: void DelayMs(unsigned t);

Header: #include "7188xc.h"

Description: Delay time unit is ms.

t: the delay time.

Example: Please refer to "TimerOpen()" function for more detailed information.

• Delay()

Function: Inserts a delay for a specific time interval. The time unit is ms and uses Timer 1 feature of the CPU.

Syntax: void Delay(unsigned ms);

Header: #include "7188xc.h"

- Description: Inserts a delay for a specific time interval. The time unit is ms and uses the Timer 1 feature of the CPU. ms: the delay time.
- Example: Please refer to "TimerOpen()" function for more detailed information.

• Delay_1()

Function: Inserts a delay for a specific time interval. The time unit is 0.1 ms and uses the Timer 1 feature of the CPU.

Syntax: void Delay_1(unsigned ms);

Header: #include "7188xc.h"

- Description: Inserts a delay for a specific time interval. The time unit is 0.01 ms and uses the Timer 1 feature of the CPU. ms: the delay time.
- Example: Please refer to "TimerOpen()" function for more detailed information.
- Delay_2()

Function: Inserts a delay for a specific time interval. The time unit is 0.01 ms and uses the Timer 1 of the CPU.

Syntax: void Delay_2(unsigned ms);

Header: #include "7188xc.h"

Description: Inserts a delay for a specific time interval. The time unit is 0.01 ms and uses the Timer 1 feature of the CPU. ms: the delay time.

Example: Please refer to "TimerOpen()" function for more detailed information.

StopWatchStart()

Function: Starts using a StopWatch channel, and resets the StopWatch value to 0.

Syntax: int StopWatchStart(int channel);

Header: #include "7188xc.h"

Description: The system timer ISR will increment the StopWatch value by 1 in 1 ms intervals.

channel: 0-7, a total of 8 channels.

Return Value: On success, returns NoError.

If the channel is out of range, returns ChannelError (-15).

Example:

```
#include "7188xc.h"
void main(void)
```

{

```
unsigned long value;
int quit=0; InitLib();
Print("\n\rTest the StopWatch ... Press 'q' to quit\n\r ");
TimerOpen();
StopWatchStart(0); /*start using the StopWatchStart function*/
while(!quit){
    if(Kbhit()){ switch(Getch()){ case 'q': quit=1; break; } }
    StopWatchReadValue(0,&value);
    Print("SWatch=%d \r",value);
    if(value=2000){
        StopWatchPause(0);
        DelayMs(2000);
        StopWatchContinue(0); }
        if(value=4000){
        StopWatchStop(0);
        StopWatchStop(0);
```

```
DelayMs(2000);
StopWatchReset(0);
StopWatchStart(0);
}
}
TimerClose();
}
```

StopWatchReset()

Function: Resets the StopWatch value to 0.
Syntax: int StopWatchReset(int channel);
Header: #include "7188xc.h"
Description: channel: 0-7, a total of 8 channels.
Return Value: On success, returns NoError. If the channel is out of range, returns ChannelError (-15).
Example: Please refer to "StopWatchStart()" function for more detailed information.

StopWatchStop()

Function:Disables the StopWatch channel.Syntax:int StopWatchStop(int channel);

Header: #include "7188xc.h"

Description: The system timer ISR will stop to increment the StopWatch value.

channel: 0-7, a total of 8 channels.

Return Value: On success, returns NoError.

If the channel is out of range, returns ChannelError (-15).

Example: Please refer to "StopWatchStart ()" function for more detailed information.

StopWatchPause()

Function: Pauses the StopWatch.
Syntax: int StopWatchPause(int channel);
Header: #include "7188xc.h"
Description: After calling StopWatchPause(), StopWatchContinue() must be called to restart the time counter.

channel:0-7, a total of 8 channels.

Return Value: On success, returns NoError.

If the channel is out of range, returns ChannelError (-15).

Example: Please refer to "StopWatchStart ()" function for more detailed information.

• StopWatchContinue()

Function: Restarts the StopWatch.
Syntax: int StopWatchContinue(int channel);
Header: #include "7188xc.h"
Description: channel:0-7, a total of 8 channels.
Return Value: On success, returns NoError. If the channel is out of range, returns ChannelError (-15).
Example: Please refer to "StopWatchStart ()" for more detailed information.

StopWatchReadValue()

- Function: Reads the current StopWatch value.
- Syntax: int StopWatchReadValue(int channel,unsigned long *value);

Header: #include "7188xc.h"

Description: The value represents the time that has elapsed since either a StopWatchStart() or StopWatchReset() was last called.

channel: 0-7, a total of 8 channels.

Return Value: On success, returns NoError().

If the channel is out of range, returns ChannelError (-15).

Example: Please refer to "StopWatchStart ()" for detailed more information.

CountDownTimerStart()

- Function: Starts using the CountDownTimer.
- Syntax: int CountDownTimerStart(int channel,unsigned long count);

Header: #include "7188xc.h"

```
Description: channel: 0-7, a total of 8 channels.
             count: the amount of time to be counted.
Return Value: On success, returns NoError().
              If the channel is out of range, returns ChannelError
               (-15).
Example:
#include "7188xc.h"
void main(void)
{
  unsigned long value;
  int quit=0;
  InitLib();
  Print("\n\rTest the CountDownTimer...");
  Print("\n\rPress 'q' to quit\n\r");
  TimerOpen();
  CountDownTimerStart(0,1000); /*use the CountDownTimer*/
  while(!quit){
    if(Kbhit()&&(Getch()=='q')) quit=1;
    CountDownTimerReadValue(0,&value);
                                            /*reads the
                                              CountDownTimer*/
    Print("Test CountDown=%d\r",value);
    if(value==0)
      CountDownTimerStart(0,1000); /*restarts the CountDownTimer*/
  }
  TimerClose();
}
```

CountDownTimerReadValue()

Function:Reads the current value of the CountDownTimer(count).Syntax:int CountDownTimerReadValue(int channel,unsigned)

long *value);

Header: #include "7188xc.h"

Description: If the return value is 0, it means that the time has expired.

channel: 0-7, a total of 8 channels.

value: a pointer to the location where the value is to be stored.

Return Value: On success, returns NoError().

If the channel is out of range, returns ChannelError

```
(-15).
```

Example: Please refer to "CountDownTimerStart ()" function for more detailed information.

InstallUserTimer()

```
Installs a custom timer function, which will be called at
Function:
            intervals of 1ms.
            void InstallUserTimer(void (*fun)(void));
Syntax:
            #include "7188xc.h"
Header:
Description: fun: A pointer to the custom function. The function
             cannot use an input argument and cannot return a value.
Example:
#include "7188xc.h"
int Data[3]={0,0,0};
void MyTimerFun(void) /*custom timer function*/
{
  static int count[3]={0,0,0};
  int i:
  for(i=0;i<3;i++){
    Print("count[%d]=%d\r",i,count[i]);
    count[i]++;
  if(count[0]>=200){ /*LCD lamp1 blinks each 200 units*/
    count[0]=0;
    if (Data[0]==0) Data[0]=1;
    else Data[0]=0;
    lamp(1,1,Data[0]);
  }
  if(count[1]>=500){ /*LCD lamp2 blinks each 500 units*/
    count[1]=0;
    if (Data[1]==0) Data[1]=1;
    else Data[1]=0;
    lamp(2,1,Data[1]);
  }
  if(count[2]>=1000){ /*LCD lamp3 blinks each 1000 units*/
    count[2]=0;
    if (Data[2]==0) Data[2]=1;
    else Data[2]=0;
```

```
}
}
```

lamp(3,1,Data[2]);

```
void main(void)
```

```
int quit=0;
Print("\n\rTest the LCD lamp blink using user timer ");
Print("\n\rPress 'q' to quit\n\r");
InitLib(); InitLCD(); /*initial Lib & LCD*/
ClrScrn(); /*clear the LCD screen*/
TimerOpen(); /*open timer function*/
InstallUserTimer(MyTimerFun); /*install and call user timer */
while(!quit){
    if(Kbhit() && Getch()=='q') quit=1;
}
TimerClose();
```

```
}
```

{

• InstallUserTimer1C()

Function: Installs a custom timer function on interrupt 0x1c. The system timer will call int 0x1c at intervals of 55 ms.

Syntax: void InstallUserTimer1C(void (*fun)(void));

Header: #include "7188xc.h"

Description: fun: A pointer to the custom function. The function cannot use an input argument and cannot return a value.

Example: Please refer to "InstallUserTimer()" function for a similar example.

• EnableWDT()

Function: Enables the WatchDog timer.

Syntax: void EnableWDT(void);

Header: #include "7188xc.h"

Description: The WatchDog Timer (WDT) is always enabled and will be continually refreshed by the system Timer ISR. When a custom program calls EnableWDT(), the system timer ISR will stop refreshing the WDT, which must then be performed by calling RefreshWDT() from within the program, otherwise, the system will be reset by the WDT. The WDT timeout period is 0.8 seconds for MiniOS7 2.0.

Example:

#include "7188xc.h"
void main(void)
{

```
int quit=0,k;
InitLib();
if(IsResetByWatchDogTimer()) /*test whether the system has been
                                  reset by the WDT*/
  Print("reset by WatchDog timer\n\r");
EnableWDT(); /*after callng EnableWDT, Refresh WDT must be called
                 within 0.8s*/
while(!quit){
  if(Kbhit()) {
    k=Getch();
    if(k=='q') {
      Print("quit the program\r\n");
      quit=1; /*quit the program*/
    }
    else {
      Print("more than 0.8s has elapsed reset the system\r\n");
      Delay(1000); /*There has been a delay for more than 0.8s. Reset
         the system*/
    }
  }
  RefreshWDT(); /*Refresh WDT must be called within 0.8s*/
  Print("call Refresh WDT\n\r");
}
DisableWDT(); /*Disable the WDT. The system will refresh the WDT*/
Print("Call DisableWDT\n\r");
```

• DisableWDT()

}

Function: Disables the WatchDog timer.
Syntax: void DisableWDT(void);
Header: #include "7188xc.h"
Description: See the description for EnableSDT().
Example: Please refer to "EnableWDT()" function for more detailed information.

• RefreshWDT()

Function: Refreshes the WatchDog timer.
Syntax: void RefreshWDT(void);
Header: #include "7188xc.h"
Description: See the description for EnableSDT().
Example: Please refer to "EnableWDT()" function for more detailed

information.

IsResetByWatchDogTime()

Function: Checks if system has been reset by the WatchDog Timer. Syntax: int IsResetByWatchDogTime(void);

Header: #include "7188xc.h"

Description: Returns 0 when true.

Example: Please refer to "EnableWDT()" function for more detailed information.

Type 7: Files

Function	Description
GetFileNo	Retrieves total number of files stored in the Flash
GelFileNU	memory.
GetFileName	Uses the file index to retrieve the file name.
GetFilePositionByNo	Uses the file number to retrieve the file position.
CotFiloInfoRvNo	Uses the file number to retrieve the file
GetFileInfoByNo	information.
GetFileInfoByName	Uses the file name to retrieve the file information.
More	There are many other custom file functions available. Please refer to the 7188xc.h header file and the user manual on the enclosed CD, which can be found at CD:\Napdos\minios7\document\lib_ manual_for_7188xabc\index.htm for more detailed for more detailed information.

Note: The file system for MiniOS7 supports custom programs for reading files, but does not support custom programs for writing files.

• GetFileNo()

Function:Gets the total number of files stored in the Flash memory.Syntax:int GetFileNo(void);Header:#include "7188xc.h"

Description: Returns the number of files.

Example: Please refer to "GetFilePositionByNo()" for more detailed information.

• GetFileName()

Function: Uses the file index to get the file name.
Syntax: int GetFileName(int no,char *fname);
Header: #include "7188xc.h"
Description: no: The file index (The first file is index 0). fname: Buffer to store file name.
Return Value: On success, returns NoError, and stores the filename to the fname.
On error, returns -1, and does not save any data to the fname. Example: Please refer to "GetFilePositionByNo()" for more detailed information.

GetFilePositionByNo()

Function: Uses the file number to read the file position.
Syntax: char far *GetFilePositionByNo(int no);
Header: #include "7188xc.h"
Description: The address can be used to get the file data. no: The file index (The first file is index 0).
Return Value: On success, returns the starting address of the file. On error, returns NULL.

Note: If the file size is > 64K-16, a huge pointer (char huge *) data type must be used to retrieve the file data for the offset.

```
Example:
#include "7188xc.h"
static FILE_DATA far *fdata; /*file_data structure, please see the file.c
                                 for details*/
char far *fp no;
void main()
{
  int fileno.i;
  char fname[13];
  InitLib(); /*Initialize the Library*/
  fileno=GetFileNo(); /*get file number*/
  Print("Total file number=%d\n\r",fileno);
  fname[12]=0;
  for(i=0;i<fileno;i++){</pre>
    fdata=GetFileInfoByNo(i); /*get file information using the file
                                 number*/
    if(fdata) {
      GetFileName(i,fname); /*get file name*/
      Print("[%02d]:%-12s start at %Fp "
           "%02d/%02d/%04d %02d:%02d:%02d size=%lu\n\r", i,fname,
      fdata->addr,fdata->month,fdata->day,(fdata->year)+1980,
      fdata->hour,fdata->minute,fdata->sec*2,fdata->size);
    }
  }
  for(i=0;i<fileno;i++){</pre>
    fp_no=(char far *)GetFilePositionByNo(i); /*get file position*/
```

```
if(fp_no){
    GetFileName(i,fname);
    Print("file %d [%-12s] position: [ %Fp ]\r\n",i,fname,fp_no);
    }
}
```

GetFileInfoByNo()

Function: Uses the file number index to retrieve file information.

Syntax: FILE_DATA far *GetFileInfoByNo(int no);

Header: #include "7188xc.h"

Description: no: The file index (The first file is index 0).

Return Value: On success, returns the starting address of the file information.

On error, returns NULL.

Example: Please refer to "GetFilePositionByNo()" for more detailed information.

GetFileInfoByName()

Function: Uses the file name to retrieve the file information.

Syntax: char far *GetFileInfoByName(char *fname);

Header: #include "7188xc.h"

Description: fname: The file name.

Return Value: On success, returns the starting address of the file information.

On error, returns NULL.

Example: Please refer to "GetFilePositionByNo()" for more detailed information.

Type 8: Connecting to I-7000/I-87K series module

Function	Description			
SendCmdTo7000	Sends a command to an I-7000/I-87K series			
Sendemanorooo	module.			
ReceiveResponseFrom7000_ms	Receives a response from an I-7000/I-87K			
Receiver esponser to 117 000_111s	series module			
ascii_to_hex	Converts the ASCII code to a hexadecimal			
	value.			
hex_to_ascii	Converts a hexadecimal value to ASCII code.			
	There are many other functions related to			
	connecting to I-7000/I-87K series module.			
	Please refer to the 7188xc.h header file and			
More	the user manual on the enclosed CD, which			
	can be found at CD:\Napdos\minios7\document			
	\lib_manual_for_7188xabc\index.htm for more			
	detailed information.			

SendCmdTo7000()

Function: Sends a command to an I-7000 series module.

Syntax: int SendCmdTo7000(int iPort, unsigned char *cCmd, int iChksum);

Header: #include "7188xc.h"

Description: If the checksum is enabled, the function will add 2 bytes checksum to the end of the command.

iPort: 0/1/2/3/4 for COM0/1/2/3/4.

cCmd: The command to be sent (DO NOT add "\r" at the end of the cCmd as SendCmdTo7000() will add a checksum (if needed) and "\r" after the cCmd).

iChecksum: 1 for checksum enabled, 0 for checksum disabled.

Return Value: On success, returns NoError.

On error, returns an Error code. Refer to the user manuals for I-7000 series modules for more details.

Example:

```
#include "7188xc.h"
void main()
{
```

```
int port=2,quit=0,x;
```

char k;

InitLib();

InstallCom(port,115200L,8,0,1); /*install a COM Port for the I-7065D*/ ClearCom(port);

SendCmdTo7000(port, "@0100", 0); /*send a command to DO to off*/ if(ReceiveResponseFrom7000_ms(port, "@0100", 20, 0))

Print("I-7065D is not available\r\n");

while(!quit){ /*control Do*/

Print("\n\r Enter 1~5 to set [Do] on...'9' to quit\n\r");

k=Getch();

x=ascii_to_hex(k); /*convert ASCII code to hex*/ ClearCom(port);

switch(x){ /*send a command to set the I-7065D Do1~5 light to on*/
case 1: /*for command details, refer to the "I-7000 DIO manual"*/
SendCmdTo7000(port, "@0101", 0);Print("[%x]=ON",x);break;
case 2:

SendCmdTo7000(port, "@0102", 0); Print("[%x]=ON",x);break; case 3:

SendCmdTo7000(port, "@0104", 0); Print("[%x]=ON",x);break; case 4:

SendCmdTo7000(port, "@0108", 0); Print("[%x]=ON",x);break; case 5:

SendCmdTo7000(port, "@0110", 0); Print("[%x]=ON",x);break; case 9:

quit=1; Print("*quit*");break;

- } /*end of switch*/
- } /*end of while loop*/
- }

ReceiveResponseFrom7000_ms()

Function: Receives a response from the I-7000 module.

Syntax: int ReceiveResponseFrom7000_ms(int iPort,

unsigned char *cCmd, long ITimeout, int iChksum);

Header: #include "7188xc.h"

Description: After calling the SendCmdTo7000() function, the ReceiveResponseFrom7000_ms() function must be called except for commands that do not require a response.

iPort: 1 for COM1, 2 for COM2, etc.

cCmd: The response received from the I-7000 module. If checksum is enabled, the function will check and

remove the checksum. The CR is also removed. ITimeout: Sets the timeout. The unit is ms.

iChecksum: 1 for checksum enabled, 0 for checksum disabled.

Return Value: On success, returns NoError.

On error, returns an Error code. Refer to the use manuals for I-7000 series modules for more details.

Example: Please refer to SendCmdTo7000() for more detailed information.

• ascii_to_hex()

Function: Converts ASCII code to a hexadecimal value.
Syntax: int ascii_to_hex(char ascii);
Header: #include "7188xc.h"
Description: Returns an integer representing the Hex value. ascii: The ASCII code char
Example: Please refer to SendCmdTo7000() for more detailed information.

Appendix E: Compiling and linking

Using the TC Compiler

There are two procedures for using the TC compiler, TC 2.01, which are described as follows:

Method 1: Using a command line (For more information, please refer to CD:\8000\NAPDOS\7188XABC\7188XC\Demo\BC_TC\Hello_C\gotc.bat) *tcc -lc:\tc\include -Lc:\tc\ib hello1.c ...\ib\7188xcl.lib*

Method 2: Using the TC Integrated Environment

Step 1: Execute TC.EXE to run the TC 2.01 Integrated Environment.

Step 2: Edit the Project file (Add the necessary library and files to the project).

C:\WINDOWS\System32\cmd.exe - d:\tc20\tc						- 🗆 ×		
File	Edit	Run	Compile	Project	t Option dit	ns Debug	Break/wat	tch
LED.C	ne 2 188xal.]		19 Inse	rt Indent	Tab Fill	Unindent	* D:NONAME.(3
					sage ——			
F1-Help	F5-Zoom	F6 -	Switch	F7-Trace	F8-Step	F9-Make	F10-Menu	MUM

Step 3: Save the project as a Project file by selecting "save" from the File menu and entering a name, such as LED.prj.


C:V	C:\WINI	DOWS\Syst	tem.32\a	md.exe - d:\tc	20\tc				- 🗆 🗙
	File	Edit	Run	Compile	Project	O ptions	Debug	Break/watch	
1	Sau Write Direc	to tory e dir	Col ABCN7:	Rename NO		b Fill Un	indent *	D:NONAME.C	

Step 4: Load the Project by selecting the project name from the Project menu.

C:\WINDOWS\System32\cmd.exe - d:\tc20\tc 🗾 🗙						
File Edit Run Com	mpile Project Options	Debug Break/watch				
Line 1 Col 1 LED.C \lib\7188xal.lib	Insert Project name Break make on Auto dependencies Clear project Remove messages	LED.PRJ Errors s Off				


Step 5: On the compiler options menu, change the Memory model to Large and set the Code Generation to 80186/80286 as shown in the diagram below.

File Edit	Run Compile	Project Opti	ons Debug Bre	ak/watch
Line 1	Col 1 Insert	Indent Ta	piler NO	NAME.C
			odel L efines ode generation ptimization ource erors ames	arge



Step 6: Select "Build all" from the compile menu to build the project.

C:\WINDOWS\System32\cmd.exe - d:\tc20\tc					- 🗆 X			
File	e <mark>E</mark> dit	Run	Compile	Project	<mark>O</mark> ptions	Debug	Break/watch	
	Line 1	Co 1	Compile to Make EXE f Link EXE f Build all Primary C Get info	ile ile	D:NONAME.OB D:DEMO5.EXE	-	D:NONAME.C	



Using the BC++ Compiler

The procedures for using the BC++ compiler is as follows:

Step 1: Execute the Borland C++ 3.1.




Step 2: Create a new project file (*.prj).


Command Pro	ompt - bc			_ 🗆 🗙
≡ File E d	lit Search (Run Compile Debug C:DOCUME~1\ADMINI~1\	Project Options Open project Close project Add item Delete item Local options Include files	Window Help 8

۲ (•)	Open	Project	t File	
<pre>open Project *.PRJ</pre>	File			
*.PRJ				OK
	_			
HELLO1.PRJ				
				Cancel
			2	Help
D:\7188E\MINIC	DS7\D	EMONBON		*.PRJ
HELLO1.PRJ		4077 H	pr 26,2	005 1:14pm


Step 3: Add all the necessary files to the project.




Step 3.1: Select the source file.




Step 3.2: Select the function library and then click the **Done** button.




Step 4: Set the Code generation options.




Step 4.1: Change the Memory model to Large.




Step 5: Set the Advanced code generation options.



Step 5.1: Set the Floating Point to Emulation and the Instruction Set to 80186.




Step 6: Set the Entry/Exit Code Generation option.



Step 6.1: Set the DOS standard.

[1]===== Entry/Exit Code Generation ======
Prolog/Epilog Code Generation
(•) DOS standard (> DOS overlay
() Windows all functions exportable
 Vindows explicit functions exported Vindows smart callbacks
() Windows DLL all functions exportable
〈 〉 Windows DLL explicit functions exported
Calling Convention Stack Options
(•) C [X] Standard stack frame () Pascal [] Test stack overflow
() Register
OK _ Cancel _ Help _


Step 7: Set the Debugger Options.



7.1 Set Source Debugging to None.



Step 8: Make the project




Linking EXE file : HELLO1.EXE Linking : \BC31\LIB\CL.LIB Lines compiled: 1257 PASS 2 Warnings: 0 0 Errors: 0 0 Available memory: 1977K Success : Press any key

Using MSC Compiler

The working steps to use MSC 6.00 Compiler are given as following:

Step 1: In the source file folder, create a batch file called Gomsc.bat using the text editor.




NOTE: /C: don't strip comments /Gs: no stack checking /Fpa: calls with altmath /Fm: [map file] /G1: 186 instructions /AL: large model

Step 2: Run the Gomsc.bat file.

```
C:\VINDOWS\System32\cmd.exe
C:\7188XA\Demo\MSC\Hello>Gomsc
C:\7188XA\Demo\MSC\Hello>cl /c /Gs /FPa /Fm /G1 /AL Hello.c
Microsoft (R) C Optimizing Compiler Version 6.00
Copyright (c) Microsoft Corp 1984-1990. All rights reserved.
Hello.c
C:\7188XA\Demo\MSC\Hello>link /MA /NOE /NOI Hello,,,..\lib\7188xal;
Microsoft (R) Segmented-Executable Linker Version 5.10
Copyright (C) Microsoft Corp 1984-1990. All rights reserved.
C:\7188XA\Demo\MSC\Hello>del *.obj
C:\7188XA\Demo\MSC\Hello>del *.map
C:\7188XA\Demo\MSC\Hello>__
```

Step 3: A new executable file will be created if it is successfully compiled.




Using MSVC++ Compiler

The working steps to use MSVC 1.50 compiler are given as following:


Step 1: Run MSVC.exe



Step 2: Create a new project (*.mak) by entering the name of the project in the Project Name field and then select MS-DOS application (EXE) as the Project type.



Step 3: Add the user's program and the necessary library files to the project.



Step 4: Set the Code Generation on the Compiler.

Project Options		×	
Project Type: MS-DOS app Use Microsoft Foundation Customize Build Options – Compiler Linker Resources	n Classes Build Mode C Debug C/C++ Compiler Option Build Options: C Debu Options String:	OK Cancel Help s g Specific • <u>R</u> elease Specific • <u>C</u> omr 70x /D "NDEBUG" /D "_DOS" /FR	mon to Both OK Cancel Help
			Use Project De <u>f</u> aults
	Category: Code Generation Custom Options Custom Options (C++) Debug Options Listing Files Memory Model Optimizations P-Code Generation Precompiled Headers Preprocessor Segment Names	Category Settings: Code Generation CPU: 80186 / 80188 Calling Convention: C / C++ * Floating-Point Calls: Use Emulator * Struct Member Byte Alignment: 2 Bytes *	 Check Pointers ✓ Disable Stack Checking Code Generator: Auto Select *

Step 5: Change the Memory model to Large.

C/C++ Compiler Options	×
Build Options: <u>Debug Specific</u> <u>Release Spec</u> Options <u>String:</u> /nologo /Gs /G1 /W3 /AL /Ox /D "NDEBUG" /D "_D	Cancel
Custom Options (C++)	gment Setup: S == DS [×]

Step 6: Remove the xcr, afxcr library from the Input Category.


Linker Options		×
_	ug Specific	
Options <u>String</u> : [/LIB:"ver" /LIB:"afver" /L	IB:"oldnames" /LIB:"slibce" /NOI /STACK:5120	
/ONERROR:NOEXE OL		
	Use Project Defau	ults
C <u>a</u> tegory: Input Memory Image Miscellaneous Output	Category Settings: Input Libraries xcr, afxcr, dnames, slibce Ignore Default Libraries Specific Libraries to Ignore: Prevent Use of Extended Dictionary V Distinguish Letter Case	

Linker Options		X
Options <u>S</u> tring:	ebug Specific	oth OK Cancel <u>H</u> elp ↓ Use Project De <u>f</u> aults
C <u>a</u> tegory: Input Memory Image Miscellaneous Output	Category Settings: Input Libraries oldnames, slibce Ignore Default Libraries Specific Libraries to Ignore: Prevent Use of Extended Dictionary Distinguish Letter Case	

Step 7: Remove the OLOGO option from the miscellancous Category.

Linker Options		×						
	bug Specific 💿 <u>R</u> elease Specific 💿 <u>C</u> ommon to Both 📃 OK							
Options <u>S</u> tring: [/LIB:"ver" /LIB:"afver" /	LIB:"oldnames" /LIB:"slibce" /NOI /STACK:5120							
/ONERROR:NOEXE OL	GO							
	Use Project Def	aults						
C <u>a</u> tegory:	Category Settings: Miscellaneous							
Input Memory Image Miscellaneous Output	Suppress Display of Sign-On Banner Other Option 5: OLOGO							

Step 8: Rebuild the project.





Compiling on 64-bit platform like Windows 7 or Winodows 8 / 8.1

Preface:

If we try to use 16-bit compiler like BC3.1 or TC++3.0 to build MiniOS7 project on Windows 64-bit platform like Windows 7 or Windows 8, it will prompt up an error message to show compatibility problem for 64-bit platform.

"Application can't run on your PC. Contact with your software publisher" Or like below snap shot.

Unsupported 16-Bit Application	×
The program or feature "\??\D:\BC\Bin\BC.EXE" cannot start or run due to incompatibity with 64-bit versions of Windows. Please contact the software vendor to ask if a 64-bit Windows compatible version is available.	
ОК	

Please follow below steps to solve the problem.

Step 1: download and install DosBox for Windows. You can easily install the 32 bit version on a 64-bit OS. The download page is here:


http://sourceforge.net/projects/dosbox/files/dosbox/0.74/DOSBox0.74-win32-installer.exe/down load

Note: Strongly recommend installing DOSBox as administrator.


	Open
8	Run as administrator
	Pin to Taskbar
	Pin to Start Menu
	Send to +
	Cut
	Сору
	Delete
	Open file location
	Properties



Step 2: Start up the DOSBox, click DOSBox **DOSBOX 0.74**, it will bring out two Windows forms, one is DOSBox Status Window and DOSBox Console as below.




First use command "CLS" or "cls" to clear the screen.



Step 3: Configure the DOSBox Environments settings.

- 1. Make sure the demo file path, for example D:\MiniOS7\hello\hello_c
- 2. Make sure the BC\Bin file path, for example D:\BC\Bin
- 3. Use mount command to mount the disk driver for example "mount d d:\"
- 4. After mount disk driver D, then type "D:" to change "Z:\>" to "D:\>".
- 5. Set Path to BC\Bin for example "path d:\bc\bin"
- 6. Change directory to demo run "bc"

🔛 DOSBox 0.74, Cpu speed: 3000 cycles, Frameskip 0, Program: DOSBO – 🗆 🗙
Z:N>mount d d:N Drive D is mounted as local directory d:N
Z:>>d:
D:\>path d:\bc\bin
D:N>cd minios7NhelloNhello_c
D:\MINIOS7\HELLO\HELLO_C>bc



Step 4: Press "Project" to open project → Press "Compile" to build the project.

·	u speed: max 100% cycles, Frameskip 0, Program: earch Run Compile Debug Project Options	
	NONAMEOO.CPP	1
	EXE file : HELLO.EXE	
	Linking : NBCNLIBNCL.LIB	
	Total Link Lines compiled: 1690 PASS 2 Warnings: 0 0	
1:1	Errors: 0 0 Available memory: 2025K	2=[†]-
File name L • HELLO.C .	Success : Press any key	Code Data 110 185
8000A.LIB .	.N. <mark>.NLIB n/a</mark>	n∕a n∕a
F1 Help Alt-F8 N	ext Msg_Alt-F7 Prev Msg_Alt-F9 Compile_F9	9 Make F10 Menu


BOSBox 0.74, 0			Compile	Debug	Pro ject	-		
	F3 F2 		NUNA	ME00.CP	r			 _
1:1 File name • HELLO.C 8000A.LIB	Location 	-	— Proje	ct: HEL	L0 ———	Lines 47 n⁄a	Code 110 n⁄a	—2=111 Data 185 n∕a
F1 Help Exit :	Borland ()++						

Tips for using batch file:

It is a little troublesome to set the path and launch the BC demo project, We can make a batch file as below for demo program,

path d:\bc\bin cd minios7\hello\hello_c bc

and save this batch file to path "D:\", when Driver D is mounted as local directory and change to d:,




After execute the bc.bat file, the demo project will be launched successfully.

B DOS	Box 0.74,	Cpu speed	l: max	100% cycle	es, Fram	eskip 0, F	program:	BC -	
≡ Fi	le <mark>E</mark> dit	Search	R un			Pro ject	Options	Wind	ow <mark>H</mark> elp
				Nonam	EOO.CPP				1
	- 1:1								
[[]]=				— Projec	t: HELL	.0 0.			
File • HELL	name	Location	n				Lines 47	Code 110	Data 185
).LIB		IB				n⁄a	n⁄a	105 n⁄a
							10 Q		
F1 Hel	o Ins Ad	ld Del De	elete	^O Optio	ns Sna	ce Inclu	des 🚽	Edit F	10 Menu
1101				- Spero	no opo		1		20 . 20114

If BC3.1 compiler is not available, it can download Free TurboC++3.0 from website Download Free **turboc.zip** from following link <u>http://www.bestfreewaredownload.com/download/t-free-turbo-c--freeware-flggsdpz.html</u>

<u>« back</u>
Turbo C++ 3.0 freeware download
The download should start automatically in a few seconds.
If it doesn't, click <u>here</u> to start the download process manually.
Alternative download 1
Alternative download 2
Alternative download 3

After unzip the turboc.zip and copy the turboc folder to D:\, then start up the DOSBox, and run the install.exe to install TC++3.0




Below snap shots are steps for install TC++ 3.0

🔀 DOSBox 0.74, Cpu speed: 3000 cycles, Frameskip 0, Program: INSTALL – 🗆 🗙
Turbo C++ 3.0 Installation Utility
Copyright (c) 1992 by Borland International, Inc.
Install Utility Welcome to the Turbo C++ 3.0 installation program. This program will install Turbo C++ on your system. You will need about 10.5 megabytes of disk space if you wish to install all available options. This includes 1 megabyte needed for workspace during the install. Press ENTER to continue, ESC to quit.
ENTER-Continue ESC-Cancel


🗱 DOSBox 0.74, Cpu speed: 3000 cycles, Frameskip 0, Program: INSTALL – 🗆 🗙		
Turbo C++ 3.0 Installation Utility		
Enter the SOURCE drive to use: \underline{D}		
Description — Enter the drive from which you wish the INSTALL utility to copy files.		
Typically, this is the drive that contains the INSTALL disk.		
ENTER-Select ESC-Cancel		


🔀 DOSBox 0.74, Cpu speed: 3000 cycles, Frameskip 0, Program: INSTALL – 🗆 🗙			
Turbo C++ 3.0 Installation Utility			
Enter the SOURCE Path			
Description — Enter the path to the directory containing the Turbo C++ files.			
ENTER-Select ESC-Cancel			

🖼 DOSBox 0.74, Cpu speed: 3000 cycles, Frameskip 0, Program: INSTALL – 🗆 🗙
Turbo C++ 3.0 Installation Utility
Directories [D:\TC] Options [IDE CMD LIB CLASS BGI HELP EXMPL] Start Installation
Description — Selecting this option will begin copying files to your hard drive into the
directories specified above.
F1-Help F9-Start the installation ENTER-Select ESC-Previous



After installed the TC++3.0, then set the Environment Path and change to demo path to run TC compiler IDE.





Appendix F: Glossary

1. AsicKey:

The I/O expansion bus supports AsicKey. The AsicKey equips a complex machine for validation checking. Included in this are 128 bytes of private data for the same purpose. It provides very strong protection against illegal copies. Every legal user has a unique AsicKey and unique software library, the user can self check this key, or the software library will check the key automatically. In this main, it is nearly impossible to remove the AsicKey protection.

Appendix G: Revision History

Revision	Date	Description
1.0	April 2007	First release
	February 2012	Page 6
		1. Modify DI specification.
		2. Modify Storage Temperature specification:
		Original: -40°C to +80°C
		New: -30°C to +80°C
		3. Modify Humidity specification:
		Original: 0 to 90%
		New: 10 to 90% RH(non-condensing)
	2014 <u>-</u>	 Add section 3.4 "Building project on 64-bit platform"
		 Add section "Compiling on 64-bit platform like Windows 7 or Windows 8 / 8.1" in Appendix E: Compiling and linking
		3. Add section "Appendix G: Revision History"